



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address		Site Address	
Customer:	TIDEWATER, INC	Customer:	USARC VA049 CHESTERFIELD
Address:	6625 SELNICK DRIVE ELKRIDGE MD 21075	Address:	6700 STRATHMORE ROAD NORTH CHESTERFIELD VA 23237
Phone:	614-623-9569	Phone:	410-688-0142
Service Call #:		Call Type:	
COM0177663		COM-PM	

Service Requested

VA049-01 XXXX 3Y187 PM-SA-3Y188 1-pc Chiller Air Cooled Main Roof Trane Moores Mechanical schedule 5/10

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
Commercial Planned Maintenance	PETELANGST				
Commercial Planned Maintenance	EARLWARE	M#CGAM070A	Trane	U10C14744	

Tech Notes

Site Start - 5/10/2022 11:00 AM

Site Stop - 5/10/2022 1:30 PM

Arrived on site and met with the site tech. Proceeded to perform pm on chiller. All electrical connections were checked and tightened, no issues found with contractors or connections. Verified pressure transducer and all sensor calibrations and verified condenser fan vfd functions. Checked fault history for any issues and only found low leaving water temp alarms(no issues just no heat load in the building). All operations are good No discrepancies were noted.

Work order is complete.

Labor

Date	Technician	Description	Hours
5/10/2022	EARL WARE	REGULAR HEAVY COMMERCIAL LABOR	2.50

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	Ssg Clay	Signature		Date	5/10/2022