



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address	Site Address
Customer: TIDEWATER, INC Address: 6625 SELNICK DRIVE Phone: ELKRIDGE MD 21075 614-623-9569	Customer: USARC VA099 BEDFORD Address: 1117 HARMONY LANE Phone: BEDFORD VA 24523 410-688-0142
Service Call #: COM0179118	Call Type: COM-PLMB

Service Requested

WORKORDER - 17331 NTE- 450

PROBLEM
QUOTE TO INSTALL SAFTEY VALVE - WH2

5/20 HH - WAITING FOR QUOTE TO BE SUBMITTED

5/25SC-WIP

6/2 NH - CALLED MARK AND REMINDED HIM THAT WE NEED THIS QUOTE.

6/6 NH - CUSTOMER EMAILED IN ASKING FOR QUOTE AGAIN - CALLED MARK, HE PROMISED TO GET THIS TO ME BY THE END OF THE DAY.

6/8SC- PER MARK, HE GOING TO HAVE TO REACH OUT TO A DIFFERENT VENDOR FOR PARTS. FERGURSON DATE FOR PART TO COME IN WAS REALLY LONG TO WAIT.

7/1SC- WANT BE ABLE TO HAVE A TECH OUT UNTIL THE WEEK OF THE 11TH.

7/19SC- TECH HAS TO UPDATE NOTES

7.22 CH QUOTE SUBMITTED

7/29SC-QUOTE APPROVED

\$1,558.83

Customer requested a relief valve replacement on the domestic hot water boiler storage tank and relocating the safety valve on the outlet side of domestic hot water piping.

Moore's is proposing to return to site and replace the relief valve. Once repairs are made, technician will test and ensure proper operations

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
PLUMBING CALL	CHRISSAUND				

Tech Notes

Tech: MARK YOUNGER, Date: 5/16/22 9:14 AM - Will work up quote

Tech: CHRISTOPHER SAUNDERS, Date: 7/22/22 2:50 PM - Worked up quote for customer

Tech: CHRISTOPHER SAUNDERS, Date: 8/18/22 8:31 PM - Installed safety valve on domestic hot water boiler in the 110 mechanical room

Labor

Date	Technician	Description	Hours
5/16/2022	MARK YOUNGER	COMMERCIAL TRAVEL TIME	0.50
5/16/2022	MARK YOUNGER	REGULAR PLUMBING LABOR	1.00
8/18/2022	CHRISTOPHER SAUNDERS	REGULAR PLUMBING LABOR	8.00

Materials

Date	Part Number	Description	Quantity
7/26/2022	CMISCX-QUOTED GS AMOUNT	QUOTED AMOUNT SUBMITTED FOR THIS GENERAL SERVICE JOB	10.500
7/26/2022	CMISCX-TRUCK CHARGE	TRUCK CHARGE	1.000
7/26/2022	CMISCX-TRIP CHARGE	TRIP CHARGE	1.000
8/5/2022	CMISCX-NON-STOCK ITEM	LF 2X2X3/4 PXPXP TEE	1.000
8/5/2022	CMISCX-NON-STOCK ITEM	LF 2X2 PXM ADPT	1.000
8/5/2022	CMISCX-NON-STOCK ITEM	COP TEE	1.000
8/5/2022	CMISCX-NON-STOCK ITEM	COP RED FTG	1.000
8/5/2022	CMISCX-NON-STOCK ITEM	COP RED FTG 1X3/4	1.000
8/5/2022	CMISCX-NON-STOCK ITEM	COP SHORT CPLG L/STOP	2.000
8/5/2022	CMISCX-NON-STOCK ITEM	RELIEF VLV ASME	2.000
8/5/2022	CMISCX-NON-STOCK ITEM	TEMP PRESS RELIEF VALVE	1.000
8/5/2022	CMISCX-NON-STOCK ITEM	3/4FTGXF WROT COP STREET FEM ADPT	1.000
8/5/2022	TAX-S	Sales Tax for Service	1.000
8/18/2022	CMISCX-NON-STOCK ITEM	Items for PO 299364	1.000
8/18/2022	CMISCX-NON-STOCK ITEM	Items for PO 299431	1.000

Signed By	Chris Saunders	Signature		Date	8/24/2022
-----------	----------------	-----------	---	------	-----------