

**CERTIFICATION OF WORK**  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD013 Date of Visit: 8/11/20

Contractor Personnel on Site:

**Patrick Donovan**

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

**Service Calls – Service Call Number and Description**

1. WO12611

2. \_\_\_\_\_

3. \_\_\_\_\_

Boiler was left on when HVAC summer/winter turnover took place due to weather changes happening at that time. Turned boiler, gas supply and hot water pumps off. Checked building management computer and supply air to bldg. was 58 degrees.

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Donovan Date: 8/11/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Tara St. Laurent Date: 8/11/20

Signed: 

E-Mail: \_\_\_\_\_

