

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID: NY128
Building: SAUGERTIES USARC
1. JOHN A. SULLIVAN
Contractor Personnel on site:
2. MATTHEW SULLIVAN
Contractor Personnel on site:

Date of Visit: 5/12, 9/23, 10/19, 10/28, 10/31/2022
CSS: 32919 WO: _____
Service Order: ☒
Corrective Maintenance: ☐

Service Order Work Performed:

Unit: _____
Manufacturer: _____
Model: _____
Serial: _____

Description:

EXTERIOR PARKING LOT POLE LIGHTS ARE NOT OPERATING
IN MAIN PARKING LOTS & OMS AREAS.

EXTERIOR BUILDING LIGHTING IN MAIN ADMINISTRATION BLDG &
OMS AREA NOT OPERATING.


Repairs

REPLACE LED DRIVERS IN PARKING LOT POLE LIGHTS.
REPLACE PHOTO CELLS IN POLE LIGHTS. REPLACE PHOTOCELLS
FOR LIGHTING OF EXTERIOR AREAS OF PARKING LOTS, OMS
AREA, BUILDING WALLS. REPLACE LED DRIVERS IN EXTERIOR
BUILDING LIGHTS.

To be signed by the Contractor:

JOHN A. SULLIVAN
Print Name:

10/31/22
Date:


Signature:

Digital Signature:

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the work listed:

Chris Pothier AFOS
Print Name/Rank:

11/01/2022
Date:

Christopher Pothier
Signature:

Digital Signature: