



Building 208 First floor west side 15 Ton AC unit will not run.

This unit supports the 3 Classrooms on the first floor. Multiple units are on BA this weekend and are using those classrooms.

Emergency service call,

Responded Thurs 7/20 had to turn around the rain was unbearable. Received call from Vinny came Friday, Installed gauge set found system short of refrigerant, Added 26.5 lbs of R-410A brought system to proper operating temperatures and pressures. Checked classroom temperatures ok came down 5 degrees

MUA COST DATA ANALYSIS AND NEGOTIATION. THE LABOR HOURS IS WITHIN THE LOCAL SCA WAGE RATE FOR THE WORK DURATION PROPOSED WHICH IS TO CHECK SYSTEM REFRIGERANT LEVEL AND ADD 26.5 LBS OF R-410A TO SYSTEM AND CHECK FOR PROPER OPERATION. TEMPERATURE ERROR. THE MEANS AND METHODS PROPOSED FOR THIS REPAIR WORK IS TYPICAL OF WORK COMPLETED AT OTHER NY FACILITIES AND CONSIDERED FAIR AND REASONABLE.



**Fahrenheit Incorporated**  
**85 Farless Ave**  
**Old Bridge N.J.08857**  
**Telephone (732) 673- 9318**  
**E-mail: Celcius60@aol.com**



| To:            |  |
|----------------|--|
| CMI/ Joe Bayne |  |
| Fort wadsworth |  |

**DUE DATE**  
**08/15/23**

CSS# 94362---WO#--23754

| P.O. #  | Invoice #  | Date                        | Project                                    |
|---|--|-----------------------------|--|
|   |  | Thurs—Friday 7/20—7/21-2023 | 15 ton DX unit located on side of bldg#208 |
| Job   |  | Rate                        | Amount                                     |
| Description   |  |                             |  |
| Emergency service call responded thurs 7/20 had to turn around the rain was unbearable. Received call from vinny came Friday, Installed guage set found system short of refrigerant, Added 26.5 lbs of R-410A brought system to proper operating tempertures and pressures. Checked class room tempertures ok came down 5 degrees | Regular price per lb of R-410A--\$100.00 Discount price to customer is \$75.00 per lb total pounds added to system 26.5 lbs. Total cost \$1987.50. No charge for Thursday 7/20 Labor for Friday 7/21--\$400.00 ----Total cost to customer--\$2387.50 |                             |  |
|   | <b>Subtotal</b>  |                             | <b>\$ \$2387.50</b>                        |
|   | <b>Tax</b>   |                             |  |
|   | <b>Total Due \$2387.50</b>   |                             |  |

Thank you for your business.