

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 8/18/23

Contractor Personnel on Site:

- | | |
|---------------|----------|
| 1. <u>JCI</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 93950 WO# 22730

Description of Repairs

The mechanics were onsite yesterday for repair on circuit 2 and were able to get that circuit running. Circuit 1 does have a leak and we are currently working on getting a quote for the leak repair and refrigerant needed. However, there are controls issues on the BMS. We can look into providing a quote to have Metasys installed on site to control the chiller, AHUs as well as the VAVs.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 8/18/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Noah Ingerson / AFOS Date: 8/18/2023

Signed: Noah Ingerson

E-Mail: _____