

CASTO TECHNICAL SERVICES, INC.

SERVICE REPORT

DATE 2024 8 20 ARRIVAL TIME DEPARTURE TIME JOB/TCK. NO. 211061

CUSTOMER P.O. NO. _____

JOB NAME/LOCATION USARC - Cross Lanes WV006

SERVICE REQUESTED (24) *Investment is to install Conduit, Wiring, a Breaker, and wire up a Phase Monitor on the Air Compressor in the*

Manufacture:			
Model#:			
Serial#:			
Refrigerant Added:	Qty	lb	oz
Refrigerant Removed:	Qty	lb	oz

- Leak Tested**
- Leak Found**
- Leak Repaired**

Method: _____

Total Charge: _____

WORK PERFORMED/UNIT INFO

wired up phase monitor betco ran conduit and wired up new breaker both compressor running and not tripping had wrong voltage phase monitor orderd correct one

NATURE OF WORK

Regular Service _____

Quoted Service _____

Start-up/Warranty _____

SPD _____

Contract Service _____

Energy Management _____

PARTS, MATERIALS AND SUBCONTRACTED SERVICES

SUMMARY OF TIME

JOB COMPLETE

YES _____ NO X EXPLAIN _____

SIGNATURE _____

Customer Representative