

SERVICE REPORT

DATE 2024 11 27 ARRIVAL TIME _____ DEPARTURE TIME 10:30 JOB/TCK. NO. 215526

CUSTOMER P.O. NO. *FEMS2966057*

JOB NAME/LOCATION *USARC - Lewisburg*

SERVICE REQUESTED *No Heat call- Arrived on site to find the Daikin System in a UE Code. Which is a disruption of "communication causing*

Manufacture: <u>Daikin</u>				
Model#: <u>REMQ72PATJ</u>				
Serial#: <u>A000298</u>				
Refrigerant Added:	Qty	lb	oz	TYPE
Refrigerant Removed:	Qty	lb	oz	TYPE

☐ Leak Tested

☐ Leak Found

☐ Leak Repaired

Method: _____

Total Charge: _____

WORK PERFORMED/UNIT INFO.

Arrived on site and checked in with customer. Customer showed me where equipment is. Went to outdoor unit looked over wiring and checked power. Went to indoor controller and had a communication loss on all head units. Went to units and had no power on them. Found breaker that was off in panel labeled air handlers. Talked to customer and someone had been in recently to change out an entry heater and had some breakers off. Turned breaker on and got power to units. Units stayed in stand by so i cycled power to controller and units started running after a couple minuets. Confirmed smooth operation and made sure rooms got up to set point. Cleaned up tools and equipment checked out with customer did paper work and left.

NATURE OF WORK

Regular Service _____
Quoted Service _____
Start-up/Warranty _____
SPD _____
Contract Service _____
Energy Management _____

PARTS, MATERIALS AND SUBCONTRACTED SERVICES

[illegible]

SUMMARY OF TIME

[illegible]

JOB COMPLETE YES X NO _____ EXPLAIN _____

SIGNATURE _____

Customer Representative