

CASTO TECHNICAL SERVICES, INC.

SERVICE REPORT

DATE 01/01/2024 ARRIVAL TIME 1:58 pm DEPARTURE TIME 2:00 pm JOB/TCK NO 215905

CUSTOMER PO. NO. FEMS# 2966272

JOB NAME/LOCATION *USARC - Abingdon VA001*

SERVICE REQUESTED

Manufacturer: Daikin
Model#: CAH008GMAM
Serial#: FB0U240401757

Refrigerant Added:	Qty	lb	oz	TYPE
Refrigerant Removed:	Qty	lb	oz	TYPE

- Leak Tested**
- Leak Found**
- Leak Repaired**

Method: _____

Total Charge: _____

WORK PERFORMED/UNIT INFO

sized to a 30 amp and will need to pull new supply wire from breaker box to starter and overloads need replaced with correct size.

Will send in quotes for all repairs

NATURE OF WORK

Regular Service _____

Quoted Service _____

Start-up/Warranty _____

SPD _____

Contract Service _____

Energy Management _____

PARTS, MATERIALS AND SUBCONTRACTED SERVICES

SUMMARY OF TIME

JOB COMPLETE

YES _____ NO _____ EXPLAIN _____

SIGNATURE _____

Customer Representative