



Service Items

Name	Description	Tier 1 Price	Unit Type	QTY	Taxable
Labor	See attached pages for details of work performed.	\$0.00	Hour	1	N
TOTAL*:	\$0.00				

* Not including taxes



Service Forms

Daily Form	Fill out every day, even on PMs, and projects
TECH NAME	Jacob Deep
DATE	4/24/25
POINT OF CONTACT:	Scott/ Reginald
DESCRIPTION OF WORK PERFORMED	upon arrival, we shut the heating system down. drained the glycol out of the system. Installed a flush valve on both the end of the run for return and the supply for zone 3. filled the system back up and flushed all of the air out. We ran the boilers in service mode to get zone 3 up to temperature to ensure there were no air locks. upon departure, the system is operating properly
TOOLS USED	handtools M18 propress
MATERIALS USED OR PICTURE OF TAG*	2) 3/4" webstone propress flush valves
HOURS	REGULAR: OVERTIME:



Attachments



Service Items

Name	Description	Tier 1 Price	Unit Type	QTY	Taxable
Labor	See attached pages for details of work performed.	\$0.00	Hour	1	N
TOTAL*:	\$0.00				

* Not including taxes



Service Forms

Daily Form	Fill out every day, even on PMs, and projects
TECH NAME	Jacob Powell
DATE	04-24-2025
POINT OF CONTACT:	Reginald Cook
DESCRIPTION OF WORK PERFORMED	installed 2 new flush valves for the glycol boiler loop going to the lactation room. turned the boiler pumps on and bled out all air that was in the lines after installing the new valves and checked that the lactation room radiator was getting hot when we fired the boiler back up. at this time, the lactation room radiator is working again, and the glycol loop is back open again as well with no leaks.
TOOLS USED	hand tools, glycol transfer pump
MATERIALS USED OR PICTURE OF TAG*	on Jake deeps daily
HOURS	REGULAR: OVERTIME: