

# JOB SUMMARY



From **VSC Fire & Security, Inc.**

1201 Electric Road

Salem, VA 24153

(540) 765-1300

Job No. 30942124  
Date 9/6/2023  
Type Service Call  
PO No. CSS# 94345

Job For **US ARMY RESERVE CENTER**  
US ARMY RESERVE CENTER  
6 John Raine Drive  
Rainelle, WV 25962

## Job description

We will provide labor for up to (12) Mhrs for troubleshooting the Fire Alarm Panel displaying a trouble condition after recent power outage.

It is the intention of VSC to provide documented and fully vaccinated employees to perform all onsite/jobsite work of the contract. However, VSC does not guarantee full compliance with all parts of Executive Order 14042.

## Exclusions

1. ANY REPLACEMENT OF EXISTING DEFECTIVE MATERIALS OTHER THAN AS LISTED IN THE ABOVE SCOPE OF WORK.
2. UPGRADE TO THE EXISTING SYSTEM OR COMPONENTS.
3. ANY WEEKEND OR OVERTIME HOURS.
4. ANY DESIGN, DRAWINGS, PERMITS OR FEES.
5. SHIPPING TBD WILL BE ADDED
6. IF ADDING CELL COMMUNICATOR AND CELL SERVICE IS NOT SUFFICIENT IN THE AREA OF THE PANEL, AN EXTERNAL ANTENNA MAY HAVE TO BE ADDED AT AN ADDITIONAL COST.

**DCJS # 11-6207**

## Services

### **Alarm System - Silent Knight 5820XL-EVS**

We will provide labor for up to (12) Mhrs for troubleshooting the Fire Alarm Panel displaying a trouble condition after recent power outage.

## Files and Photos



## Comments



Eric King  
09/06/2023 11:40am EDT

Trouble on fire panel indicating short on speaker circuit - OMS Building Circuit 2. Upon troubleshooting, found speaker on exterior of OMS building with moisture and corrosion present. Removed wiring to bypass device. It doesn't appear water is completely entering the device but the outer o ring is slightly leaking allowing terminals to become wet and corrode. Will need to replace device. While on site, I check other three exterior devices and all appear to be in good condition without the presence of water or corrosion.

Speaker: System Sensor SPWK

Pictures attached for reference

---

## Disclaimers and Warranties

**General:** VSC Fire & Security, Inc. warrants that the Products furnished hereunder will be free from defects in materials and workmanship for a period of one (1) year from the date of furnishing. Products or services not in conformance with the above warranty shall be repaired, replaced, re-performed or subject to refund, at VSC Fire & Security, Inc.'s election, as Customer's sole remedy.

**Terms of Payment:** Monthly invoices will be rendered representing the value of materials delivered to the site and work performed. All such invoices are payable in full within thirty (30) days. All sums not paid when due shall bear interest at a rate of 1½% per month, or the maximum allowed by law in the jurisdiction where the Work is performed, whichever is greater.

As an exception to the standard Terms of Payment described above, all Knox® Sales are COD and payment must be made in full before products/services can be provided. This fee includes all Knox® products, sales tax and standard shipping & handling fees. This fee does not include installation.

All agreements are subject to the terms and conditions that are found at <https://vscfire.com/terms/>

---