

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TANKS, WATER STORAGE

SITE AND BLDG #: **NY052 BLDG1**MECHANIC
SIGNATURE:DATE: 12/12/23LOCATION/RM #: **bldg1** WO# **14430** ASSET # **5015**~~START TIME: 10:15am~~~~FINISH TIME: 10:30am~~

CHECK POINT	CHECKPOINT DESCRIPTION	TASK CC YES	SPECIAL INSTI
			TO BE PERFORMED AT EACH
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	
1	Examine exterior of tank including fittings, manholes, and handholes for leaks, signs of corrosion, and correct as indicated.	<input checked="" type="checkbox"/>	
2	Inspect structural supports and repair or replace damaged insulation or covering. If insulation contains asbestos and is damaged or eroded, it is considered a hazardous waste.	<input checked="" type="checkbox"/>	
3	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	<input checked="" type="checkbox"/>	
4	Clean up work site.	<input checked="" type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor) exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, To be performed by: General Maintenance Worker

Additional Notes: