

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**TANKS, WATER STORAGE**

SITE AND BLDG #: VA039-01

MECHANIC  
SIGNATURE: 

DATE: 11-SEP-2022

LOCATION/RM #: WO# 19959 ASSET # 9082

START TIME: 11AM

FINISH TIME: 12PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		
<b>TO BE PERFORMED AT EACH INSPECT</b>				
1	Examine exterior of tank including fittings, manholes, and handholes for leaks, signs of corrosion, and correct as indicated.	●		
2	Inspect structural supports and repair or replace damaged insulation or covering. If insulation contains asbestos and is damaged or eroded, it is considered a hazardous waste.	●		
3	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	●		
4	Clean up work site.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Water storage checking out well with no issues.  
 -AS

