

Griffin

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: U.S. ARMY Roseville Date of Visit: 4/8/22

Contractor Personnel on Site:

1. Michael Colic
2. _____
3. _____

4. Michael Colic
5. _____
6. Jeff Lamroux

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____

Inspection, Testing, and Certification

1. _____
2. _____
3. _____
4. _____

Other Recurring Services

1. _____
2. _____
3. _____
4. _____

Service Calls - Service Call Number and Description

1. Found bad Fire alarm sensor
2. It is keeping unit from running
3. need to call Fire alarm company to replace sensor

Griffin

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: U.S. ARMY
RESERVE

Date of Visit: 4/7/22

Contractor Personnel on Site:

1. CONTRACTOR
2. _____
3. _____

4. Michael Leslie
5. _____
6. _____

Work Performed:

~~Preventive Maintenance~~ - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. Found I needed help with control scheme
2. Needed 2 techs to figure out control
3. Very difficult due to install timeline
4. diagnosis with only 1 tech, U/Cycling across

Inspection, Testing, and Certification

1. _____
2. _____
3. _____
4. _____

Other Recurring Services

1. _____
2. _____
3. _____
4. _____

Service Calls – Service Call Number and Description

1. _____
2. _____
3. _____