



# **INSPECTION CAPABILITIES**


---




**FIRE  
ALARM**



**FIRE  
SPRINKLER**



**FIRE ALARM  
MONITORING**



**FIRE  
SUPPRESSION**



**FIRE  
EXTINGUISHER**

---

**CONTACT US TODAY FOR A QUOTE**

Phone: 607-936-1500

Online: [davisulmer.com/rfq](http://davisulmer.com/rfq)

# Fire Alarm Inspection and Testing Report



**Location Code:** TSGXROD

**Contact:** Julie Pape

**Contact Address:** 198 CORNWELL ST  
PENN YAN, NY 14527-1343

**Phone:** 904-465-1981

**Email:** julie.pape@tideh2o.net

**Property Evaluated:** USAR- Penn Yan (Assembly)  
198 CORNWELL ST  
PENN YAN, NY 14527-1343

**Description:** Fire Alarm (Fire Alarm New)

**Work Order:** 258499

**Company:** Davis Ulmer Sprinkler Co

NYS Fire Alarm License 12000281635

**Address:** 55 Riverside Dr  
Corning, NY 14830

**Company Phone:** (607) 936-1500

**Inspector:** Justin Button

N/A

**Date of Work:** 8/19/2024

**Frequency:** Semi-Annual

**Tag:** 258499

## Deficiency Summary

Please refer to the Deficiency Summary located on applicable Fire Alarm Supplementary Forms for additional deficiency details.

## General Comments

*These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.*

There are no general comments for this submission



**Davis Ulmer Sprinkler Co**  
55 Riverside Dr  
Corning, NY 14830  
Phone: (607) 936-1500

## Fire Alarm Inspection and Testing Report

### 1. Property Information

Tag 258499  
Inspection Frequency: Semi-Annual  
Property Being Evaluated:  
USAR- Penn Yan (Assembly)  
Owner:  
Julie Pape  
Owner's Phone Number:  
904-465-1981  
Property Address:  
198 CORNWELL ST, PENN YAN, NY, 14527-1343  
Assembly Description:  
Fire Alarm (Fire Alarm New)

### 2. Monitoring Information

Is there a monitoring entity?  Yes  No  
Monitoring organization: Simplex JCI  
Phone: 1-877-200-7854  
Email: -  
Account number: U687049707  
Phone line 1: -  
Phone line 2: -  
Means of transmission: -  
Entity to which alarms are retransmitted: -  
Phone: -

### 3. Notifications Made Prior To Testing

	Contact	Time
Monitoring organization:	Simplex	10:00
Building management:	USAR	10:00

### 4. System Information - Panels / Power

**Davis Ulmer Sprinkler Co**

55 Riverside Dr

Corning, NY 14830

Phone: (607) 936-1500

**4.1 Addressable Panels**

Control Unit	Manufacturer: Notifier		Model Number: NFS2-3030		Location: Panel Room			Software Revision: Current
SLC Loops	Max #: 2	# Utilized: 2	Addresses Available: -		NAC Circuits	Max #: 2	# Utilized: 2	Style/Class: B
Primary Power	Voltage: 120	Amps: 20	Overcurrent Protection Type: Breaker		Amps: 20	Disconnecting Means Location: Breaker		
Battery 1	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 1	VDC: 12.76	Ah: 85.4	Charger Voltage: 24.67	Result of Battery 1 & 2
Battery 2	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 2	VDC: 12	Ah: 92	Charger Voltage: 24.67	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Replaced
Secondary Power	Other Power Present? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Description:					

Control Unit	Manufacturer: Notifier		Model Number: NFS2-3030		Location: Garage OMS			Software Revision: -
SLC Loops	Max #: 2	# Utilized: 2	Addresses Available: -		NAC Circuits	Max #: 2	# Utilized: 2	Style/Class: B
Primary Power	Voltage: 120	Amps: 20	Overcurrent Protection Type: Breaker		Amps: 20	Disconnecting Means Location: Breaker		
Battery 1	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 1	VDC: 12.62	Ah: 93	Charger Voltage: 24.21	Result of Battery 1 & 2
Battery 2	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 2	VDC: 12.93	Ah: 87.3	Charger Voltage: 24.86	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Replaced
Secondary Power	Other Power Present? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Description:					

**4.3 Additional Power Supplies**

Are there additional power supplies?

 Yes  No

**Davis Ulmer Sprinkler Co**

55 Riverside Dr

Corning, NY 14830

Phone: (607) 936-1500

**Power Supplies**

Control Unit	Manufacturer: Notifier		Model Number: NFS2-3030		Location: Panel Room			Disconnecting Location: Panel Room
Battery 1	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 1	VDC: 12.67	Ah: 82.3	Charger Voltage: 24.65	Result of Battery 1 & 2
Battery 2	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 2	VDC: 12.65	Ah: 88.34	Charger Voltage: 24.78	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Replaced

Control Unit	Manufacturer: Notifier		Model Number: NFS2-3030		Location: Panel Room			Disconnecting Location: Breaker
Battery 1	Voltage: 12	Amps: 18	Mfr Year: 23	Load Test Battery 1	VDC: 12.56	Ah: 16.3	Charger Voltage: 24.76	Result of Battery 1 & 2
Battery 2	Voltage: 12	Amps: 18	Mfr Year: 23	Load Test Battery 2	VDC: 12.74	Ah: 15.23	Charger Voltage: 24.89	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Replaced

Control Unit	Manufacturer: Notifier		Model Number: NFS2-3030		Location: Garage OMS			Disconnecting Location: Breaker
Battery 1	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 1	VDC: 12.3	Ah: 85	Charger Voltage: 25.35	Result of Battery 1 & 2
Battery 2	Voltage: 12	Amps: 100	Mfr Year: 23	Load Test Battery 2	VDC: 12.45	Ah: 89.54	Charger Voltage: 23.67	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Replaced

Control Unit	Manufacturer: Notifier		Model Number: PSE-10		Location: Garage OMS			Disconnecting Location: Breaker
Battery 1	Voltage: 12	Amps: 18	Mfr Year: 23	Load Test Battery 1	VDC: 12.67	Ah: 16.34	Charger Voltage: 24.12	Result of Battery 1 & 2
Battery 2	Voltage: 12	Amps: 18	Mfr Year: 23	Load Test Battery 2	VDC: 12.38	Ah: 17.23	Charger Voltage: 24.12	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Replaced

**5. Testing Results****5.1 Control Unit and Related Equipment**

Description	Visual Inspection	Functional Test	Results
Control unit	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Lamps / LEDs / LCDs	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Fuses	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Trouble signals	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Disconnect switches	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Ground-fault monitoring	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Supervision	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Annunciators	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Remote power panels	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Other	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A



**Davis Ulmer Sprinkler Co**  
 55 Riverside Dr  
 Corning, NY 14830  
 Phone: (607) 936-1500

## 5.2 Secondary Power

Description	Visual Inspection	Functional Test	Results
Battery condition	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Load voltage	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Discharge test	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Charger test	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Remote panel batteries	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A

## 5.3 Alarm and Supervisory Alarm Initiating Device

Complete supplementary device test form for all initiating devices.

a. Did all tested initiating devices pass?  Yes  No  N/A

## 5.4 Notification Appliances

Include Notification Appliances Table on this Report?

Yes  No

Complete supplementary appliance test form for all notification appliances.

## 5.5 Interface Equipment

Complete supplementary interface component test form for all interface components.

*Circuit Interface / Signaling Line Circuit Interface / Fire Alarm Control Interface*

## 5.6 Supervising Station Monitoring

Description	Yes/No	Time (sec)	Results
Alarm signal	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	60	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Alarm restoration	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	60	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Trouble signal	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	60	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Trouble restoration	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	60	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Supervisory signal	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	60	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A
Supervisory restoration	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	60	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A

## 5.7 Air Sampling Detection

Is there Air Sampling Detection?

Yes  No

## 5.8 Device Information

Devices				
Pull Station Manufacturer(s) Notifier	Type <input checked="" type="checkbox"/> Keyed <input type="checkbox"/> Hex Key <input type="checkbox"/> Screw <input type="checkbox"/> Other	Detector manufacturer(s) Notifier	Notification device manufacturer(s) Notifier	Color <input checked="" type="checkbox"/> Red <input type="checkbox"/> White <input type="checkbox"/> Other
Comment				

## 6. Notifications That Testing Is Complete

	Contact	Time
Monitoring organization:	Siemens	2:00
Building management:	USAR	2:00

## 7. System Restored To Normal Operation

Date: 8/19/2024  
 Time: 2:00

## 8. Observations

*These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.*

Please see the summary section at the top of the form for the comments.

## 9. Inspector Information:

Test Verification:

Inspected By

Inspector Signature

Justin Button

Inspector License:

N/A

Date of Work

8/19/2024

**Inspection Notes**



**Davis Ulmer Sprinkler Co**  
55 Riverside Dr  
Corning, NY 14830  
Phone: (607) 936-1500

---

**Owner's Section**

Is the Owner or a representative available?

Yes  No owner available onsite

#### **SECTION IV - OTHER TERMS AND LIMITATIONS**

1. This Agreement is for inspection services only. If Customer wants Company to make any repairs, alterations or replacements as a result of the inspection services performed pursuant to this Agreement, such work and the additional compensation to Company must be specified in a separate written agreement between Company and Customer.
2. Any additional system equipment added to the Property after the date of this Agreement or not otherwise specified in Section II of this Agreement is not included in the inspection services to be provided pursuant to this Agreement. Inclusion of any such other equipment will require execution of an amendment to this agreement and adjustment of the inspection fee.
3. The inspection services provided by Company pursuant to this Agreement are limited to an evaluation of the functionality of the equipment identified in Section II above. Company will not evaluate or express any opinion as to whether the design and/or installation of the system are suitable for the Property or the operations at the Property.
4. Company's inspection is limited to a visual inspection of external readily accessible parts of the system and will not include every component including but not limited to sprinkler heads, pipe, fittings, hangers, pull stations, smoke detectors, conduit wire or other parts of the system being inspected. Company will only inspect a representative number or sample of the sprinkler heads, pipes, hangers, valves or other devices and equipment in their current position. THEREFORE, BY CONDUCTING ITS INSPECTION UNDER THIS AGREEMENT, COMPANY DOES NOT GUARANTEE OR WARRANT THE CONDITION OR OPERATION OF EVERY PIPE, SPRINKLER HEAD OR OTHER PART OF THE FIRE PROTECTION AND/OR FIRE ALARM/SECURITY SYSTEM ON THE PROPERTY.
5. AS A MATERIAL INDUCEMENT FOR COMPANY TO PROVIDE THE SERVICES SPECIFIED IN THIS AGREEMENT AT THE INSPECTION FEE QUOTED IN THIS AGREEMENT, CUSTOMER AGREES THAT COMPANY'S LIABILITY TO CUSTOMER AND ALL THIRD PARTIES WITH RESPECT TO ANY CLAIM UNDER THIS AGREEMENT, OR ARISING FROM THE SERVICES FURNISHED BY COMPANY, SHALL BE LIMITED TO THE LESSER OF \$1,000.00 OR THE TOTAL CONSIDERATION ACTUALLY RECEIVED BY COMPANY UNDER THIS AGREEMENT. THE FOREGOING LIMITATION SHALL APPLY TO ALL CLAIMS REGARDLESS OF THE NATURE THEREOF, INCLUDING CLAIMS ASSERTED AS A BREACH OF CONTRACT, A BREACH OF WARRANTY, NEGLIGENCE, STRICT LIABILITY OR OTHERWISE. IN NO EVENT SHALL COMPANY BE LIABLE FOR INCIDENTAL, CONSEQUENTIAL, SPECIAL, AND INDIRECT OR PUNITIVE DAMAGES, OR DAMAGES FOR LOST PROFITS. If Customer desires Company to accept an increased limit of liability for the services provided under this Agreement, Company will provide an alternate inspection fee quote reflecting such increased limit, provided, however, that the increased limit shall be effective only upon Company's and Customer's execution of a replacement agreement confirming the same and Customer's payment of the alternate fee.
6. Company, following each inspection, will provide to Customer a written "Report of Inspection" ("Report"). If required and/or with prior written authorization, Company will provide copies of the Report to the local or state authority having jurisdiction on behalf of Customer. If requested by Customer, a copy of the Report will also be forwarded to Customer's insurance company. The Report and recommendations, if any, by Company are only advisory in nature and are intended to assist Customer in reducing the possibility of loss to the Property by indicating obvious defects or impairments to the system(s) which were discovered by Company's inspection and which should receive prompt attention.

7. Customer agrees to obtain and shall be solely responsible to maintain property and casualty insurance for the Property, all contents therein, and operations performed within or around the Property. No insurance company, insurer or bonding company or their successors or assigns shall have any right of subrogation or otherwise against Company arising out of this Agreement or the services provided by Company pursuant to this Agreement.
8. Customer agrees to indemnify, defend and hold harmless Company, its agents, and employees from and against any and all claims, demands, suits, liabilities, damages, judgments, losses and expenses (including, without limitation, attorneys' fees) which may be asserted against or incurred by Company by any third party arising out of or related to this Agreement or the services provided by Company pursuant to this Agreement.
9. Company will make every reasonable effort to prevent the discharge of water into or onto areas of landscaping, decorative pavement, etc., at the Property, however it is Customer's responsibility to provide sufficient and readily accessible means to accept the full flow of water that may be required by tests as determined by the type of inspection and to take measures to eliminate the formation of ice in any area where a slip and fall hazard could occur.
10. This Agreement may not be assigned by Customer without the written consent of Company.
11. This Agreement may be signed in counterparts; a signed facsimile, photocopy, and/or electronic mail of this Agreement shall be as binding on both parties just as though this Agreement were executed in its original, pre-printed form.
12. This Agreement constitutes the entire Agreement between Company and Customer regarding the subject matter hereof and supersedes all prior agreements and understandings relating thereto. Although Customer for its convenience or in furtherance of its internal procedures may issue to Company a purchase order, order acknowledgement or similar form in connection with the services provided by Company pursuant to this Agreement, no term or condition in any such form that is different from or in addition to the terms set forth in this Agreement shall be applicable, and all such different or additional terms shall be ineffective and void. This Agreement cannot be amended or modified except by a writing signed by Customer and Company.
13. Customer acknowledges Company is relying upon the accuracy of the information regarding Customer and the Property set forth in Sections I of this Agreement. Customer represents that all such information is complete and accurate as of the date on which this Agreement is signed by Customer. Customer will promptly advise Company in writing of any change to such information.
14. Other inclusions, exclusions, or attachments (if any) we exclude fire alarm.