

Fire Extinguisher Inspection List



Location Code: NOCPEBT

Contact: CINDY CROYLE

Contact Address: 950 NEW CASTLE RD
FARRELL, PA 16121-1265

Phone:

Email: cynthia.a.croyle.ctr@army.mil,
reginald.cook@cmimgmt.com

Property Evaluated: USAR PA027 FARRELL (Business)
950 NEW CASTLE RD
FARRELL, PA 16121-1265

Description: Fire Extinguishers (USAR PA027 FARRELL A 4-25
EXT)

Work Order: SV2503190286

Company: GRUNAU FIRE PROTECTION

Address: 590 E WESTERN RESERVE RD, BLDG 5
BOARDMAN, OH 44514

Company Phone: 330-758-3500

Inspector: RYAN HAHN
OH FIRE - 54.78.1541

Date of Work: 4/1/2025

Frequency: Annual

Deficiency Summary

There are no reported deficiencies for this submission

Service Summary

Total Extinguishers: 18, Tested: 18, Not Tested: 0, Passed: 18, Failed: 0

In 2026: 13 are due for Hydro service.

In 2030: 3 are due for 6 yr service.
1 is due for Hydro service.

In 2031: 1 is due for Hydro service.

General Comments

These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.

There are no general comments for this submission

Fire Extinguisher Inspection List

Account Information		
Facility Name: USAR PA027 FARRELL	Property Type: Business	Location Code: NOCPEBT
Service Address: 950 NEW CASTLE RD, FARRELL, PA, 16121-1265		
Owner: CINDY CROYLE	Owner's Phone:	
Owner's Address: 950 NEW CASTLE RD, FARRELL, PA, 16121-1265		

Zone: 1

Zone: 1										
Tag	Serial Number	Model	Size	Type	Location	Last Service	Next Service	Frequency	Inspection	Comments
1	CG-622389	Amerex (2014) B456	10#	ABC	MAIN ENTRANCE	6 yr 2021	Hydro 2026	Annual	Pass	
2	CG-622416	Amerex (2014) B456	10#	ABC	1ST. FLR. BACK ENTRANCE	6 yr 2021	Hydro 2026	Annual	Pass	
3	CG-623453	Amerex (2014) B456	10#	ABC	1ST. FLR. DOWN RAMP NEAR RESTROOMS	6 yr 2021	Hydro 2026	Annual	Pass	
4	CG-622363	Amerex (2014) B456	10#	ABC	1ST. FLR. HALL NEAR RM. 148	6 yr 2021	Hydro 2026	Annual	Pass	
5	CG-622376	Amerex (2014) B456	10#	ABC	1ST. FLR. HALL NEAR RM. 141	6 yr 2021	Hydro 2026	Annual	Pass	
6	CG-623436	Amerex (2014) B456	10#	ABC	1ST. FLR. EXIT NEAR SUPPLY CAGES	6 yr 2021	Hydro 2026	Annual	Pass	
7	CG-622377	Amerex (2014) B456	10#	ABC	1ST. FLR. RAMP NEAR KITCHEN	6 yr 2021	Hydro 2026	Annual	Pass	
8	CG-622362	Amerex (2014) B456	10#	ABC	1ST. FLR. ASSEMBLY NEAR KITCHEN	6 yr 2021	Hydro 2026	Annual	Pass	
9	E-72494914	Ansul (2018) AA10S	10#	ABC	1ST. FLR. KITCHEN	6 yr 2025	Hydro 2031	Annual	Pass	
10	I-14558409	Amerex (2024) C260	6L	K	KITCHEN	New 2024	Hydro 2030	Annual	Pass	
11	I-23047396	Amerex (2024) 10 HI SA80 ABC	10#	ABC	ASSEMBLY GYM	New 2024	6 yr 2030	Annual	Pass	
12	A-23951005	Amerex (2014) B456	10#	ABC	2ND. FLR. HALL FRONT	6 yr 2021	Hydro 2026	Annual	Pass	
13	CG-611407	Amerex (2014)	10#	ABC	2ND. FLR. HALL	6 yr 2021	Hydro 2026	Annual	Pass	



GRUNAU FIRE PROTECTION
590 E WESTERN RESERVE RD, BLDG 5
BOARDMAN, OH 44514
Phone: 330-758-3500

Zone: 1											
Tag	Serial Number	Model	Size	Type	Location	Last Service	Next Service	Frequency	Inspection	Comments	
		B456			MIDDLE						
14	CG-623435	Amerex (2014) B456	10#	ABC	2ND. FLR. HALL REAR	6 yr 2021	Hydro 2026	Annual	Pass		
15	A-23950968	Amerex (2014) B456	10#	ABC	GARAGE BAY #1 FRONT ENTRANCE	6 yr 2021	Hydro 2026	Annual	Pass		
16	I-23055794	Amerex (2024) B456	10#	ABC	GARAGE BAY #2/#3	New 2024	6 yr 2030	Annual	Pass		
17	I-23048155	Amerex (2024) B456	10#	ABC	GARAGE BAY #3 REAR EXIT	New 2024	6 yr 2030	Annual	Pass		
18	A-23950991	Amerex (2014) B456	10#	ABC	BACK STORAGE GARAGE	6 yr 2021	Hydro 2026	Annual	Pass		

Comments

Any deficiencies or other problems found with the extinguishers must be explained using the comment specific for each extinguisher. Additional comments can be added here.

Please see the summary section at the top of the form for the comments.

Inspector's Information

Inspected By

RYAN HAHN

Inspector License:

OH FIRE - 54.78.1541

I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested at this time was left in operating condition upon completion of this inspection except as noted in the *Comments*.

Signature of Inspector

4/1/2025

Date

Owner or Owner's Representative

Owner or Owner's Representative Name

GARY S.

Owner or Owner's Representative Signature

4/1/2025

Date