

Fire Extinguisher Inspection List



Location Code: USSNJAP

Contact: CINDY CROYLE

Contact Address: 7001 KLIER DR, BLDG 91714
FAIRVIEW, PA 16415-2468

Phone: 412-477-7816

Email: cynthia.a.croyle.ctr@army.mil,
reginald.cook@cmimgmt.com

Property Evaluated: USAR PA209 FAIRVIEW (Business)
7001 KLIER DR, BLDG 91714
FAIRVIEW, PA 16415-2468

Description: Fire Extinguishers (UASR PA209 FAIRVIEW A 4-25
EXT)

Work Order: SV2503190286

Company: GRUNAU FIRE PROTECTION

Address: 590 E WESTERN RESERVE RD, BLDG 5
BOARDMAN, OH 44514

Company Phone: 330-758-3500

Inspector: KEVIN JUILLERAT
OH FIRE - 54.50.1882

Date of Work: 4/24/2025

Frequency: Annual

Deficiency Summary

There are no reported deficiencies for this submission

Service Summary

Total Extinguishers: 12, Tested: 12, Not Tested: 0, Passed: 12, Failed: 0

In 2027: 10 are due for Hydro service.

In 2029: 1 is due for 6 yr service.

In 2030: 1 is due for 6 yr service.

General Comments

These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.

There are no general comments for this submission

Fire Extinguisher Inspection List

Account Information		
Facility Name: USAR PA209 FAIRVIEW	Property Type: Business	Location Code: USSNJAP
Service Address: 7001 KLER DR, BLDG 91714, FAIRVIEW, PA, 16415-2468		
Owner: CINDY CROYLE	Owner's Phone: 412-477-7816	
Owner's Address: 7001 KLER DR, BLDG 91714, FAIRVIEW, PA, 16415-2468		

Zone: 1

Zone: 1										
Tag	Serial Number	Model	Size	Type	Location	Last Service	Next Service	Frequency	Inspection	Comments
1	A-24089603	Amerex (2014) 423	20#	ABC	USARC MECHANICAL ROOM 125	6 yr 2021	Hydro 2027	Annual	Pass	
2	A-24089592	Amerex (2014) 423	20#	ABC	USARC CORRIDOR NEAR CLASSROOM 109	6 yr 2021	Hydro 2027	Annual	Pass	
3	A-24089579	Amerex (2014) 423	20#	ABC	USARC CORRIDOR NEAR MECHANICAL ROOM 125	6 yr 2021	Hydro 2027	Annual	Pass	
4	A-24089664	Amerex (2014) 423	20#	ABC	USARC ADMINISTRATION	6 yr 2021	Hydro 2027	Annual	Pass	
5	A-24089667	Amerex (2014) 423	20#	ABC	USARC ASSEMBLY HALL 147	6 yr 2021	Hydro 2027	Annual	Pass	
6	I-14558800	Amerex (2024) C260	6L	K	USARC KITCHEN	New 2024	6 yr 2030	Annual	Pass	
7	A-24089580	Amerex (2014) 423	20#	ABC	USARC UNIT STORAGE 144	6 yr 2021	Hydro 2027	Annual	Pass	
8	A-24089608	Amerex (2014) 423	20#	ABC	USARC UNIT STORAGE 144	6 yr 2021	Hydro 2027	Annual	Pass	
9	CB-538039	Amerex (2014) 423	20#	ABC	OMS MAINTENANCE BAY	6 yr 2021	Hydro 2027	Annual	Pass	
10	A-24089576	Amerex (2014) 423	20#	ABC	OMS CORRIDOR NEAR B104	6 yr 2021	Hydro 2027	Annual	Pass	
11	H38721181	Badger (2023) ADV-10	10#	ABC	OMS FLAMMABLE STORAGE ROOM	New 2023	6 yr 2029	Annual	Pass	
12	A-24089663	Amerex (2014)	20#	ABC	UHS BUILDING	6 yr 2021	Hydro 2027	Annual	Pass	



GRUNAU FIRE PROTECTION
590 E WESTERN RESERVE RD, BLDG 5
BOARDMAN, OH 44514
Phone: 330-758-3500

Zone: 1

Tag	Serial Number	Model	Size	Type	Location	Last Service	Next Service	Frequency	Inspection	Comments
		423								

Comments

Any deficiencies or other problems found with the extinguishers must be explained using the comment specific for each extinguisher. Additional comments can be added here.

Please see the summary section at the top of the form for the comments.

Inspector's Information

Inspected By

KEVIN JUILLERAT

Inspector License:

OH FIRE - 54.50.1882

I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested at this time was left in operating condition upon completion of this inspection except as noted in the *Comments*.

Signature of Inspector

4/24/2025

Date

Owner or Owner's Representative

Owner or Owner's Representative Name

Owner or Owner's Representative Signature

4/24/2025

Date