

Fire Pump Inspection Report



Location Code: GNSZSYS

Contact: CINDY CROYLE

Contact Address: 6467 MIKE WOOD BLVD
CONNEAUT LAKE, PA 16316-6661

Phone: 412-477-7816

Email: cynthia.a.croyle.ctr@army.mil,
reginald.cook@cmimgmt.com

Property Evaluated: USAR PA118 CONNEAUT LAKE
(Business)
6467 MIKE WOOD BLVD
CONNEAUT LAKE, PA 16316-6661

Description: Fire Pump (USAR CONNEAUT LAKE A
06-25 FP)

Work Order: SV2504090264/1

Company: GRUNAU FIRE PROTECTION

Address: 590 E WESTERN RESERVE RD, BLDG
5
BOARDMAN, OH 44514

Company Phone: 330-758-3500

Inspector: DAN JOHNSON
OH FIRE - 54.50.1442

Date of Work: 6/12/2025

Frequency: Annual

Tag: USAR PA118 CONNEAUT LAKE
(PUMP TEST) 06-25

Deficiency Summary

Status: Open

2. Ventilating louvers in pump room appear operational?

Never opened upon starting of pump

Status: Open

Is the net pressure test result, adjusted for the speed of the pump, at or above 95% of the Rated pressure at the rated flow of the pump?

Under net pressure

General Comments

These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.

There are no general comments for this submission

Fire Pump Inspection Report

Tag

USAR PA118 CONNEAUT LAKE (PUMP TEST)

06-25

Annual

Inspection Frequency:

Property Being Evaluated:

USAR PA118 CONNEAUT LAKE (Business)

Owner:

CINDY CROYLE

Owner's Phone Number:

412-477-7816

Property Address:

6467 MIKE WOOD BLVD, CONNEAUT LAKE, PA, 16316-6661

1. General

A. (To be filled out by the Owner or Owner's Representative)

Has the Owners section been answered on another inspection report that will be submitted with this inspection report?

Yes No

B. (To be answered by the inspector)

1. Is System in service upon arrival?

Yes No

C. Fire Pump Information

1. Fire pump shaft
2. Fire pump Manufacturer
3. Fire pump Model/Type
4. Fire pump serial number
5. Impeller diameter
6. Fire pump rated GPM
7. Fire pump rated RPM
8. Fire pump rated PSI:
 - a. Fire pump rated PSI at churn
 - b. Fire pump rated PSI at 100%
 - c. Fire pump rated PSI at 150%
9. Suction from
10. Tank size
11. Tank height
12. Is this a Vertical Turbine Type?

Horizontal Vertical

AC (XYLEM)

393H / 6100

21-090471-01-01 / L7926P

17.70

1500

1760

141

125

105

WELL / TANK

UNKNOWN

UNKNOWN

Yes No

D. Driver Information

Driver manufacturer

Driver model or type

Driver serial number

Driver rated HP

Driver rated RPM

Driver engine type

Driver rated voltage

Driver operating voltage

Driver Phase

Drive Cycles

Driver service factor

CLARKE

JU6H-UFADNG

PE6068N016344

190

1760

Electric Diesel

N/A

N/A

N/A

N/A

N/A

E. Controller Information

Controller manufacturer

Controller model or type

Controller serial number

Controller Start PSI

Controller Stop PSI

TORNATECH

DM

WZ1147429

155

175

F. Jockey Pump Information

1. Is there a Jockey Pump?
2. Jockey pump manufacturer
3. Jockey pump model or type
4. Jockey pump serial number
5. Jockey pump on PSI
6. Jockey pump off PSI

Yes No

GOULDS (XYLEM)

E-SV

C2006291

165

175

2. - Inspector's Section

A. Inspections - All to be performed weekly

1. Pump house/room proper temperature? Yes No N/A
 2. Ventilating louvers in pump room appear operational? Yes No N/A
 3. Pump suction, discharge, and bypass valves are open? Yes No N/A
 4. Piping free from leaks? Yes No N/A
 5. Suction and system pressure gauges normal? Yes No N/A
 6. Suction reservoir, if provided, is full? Yes No N/A
 7. Wet pit suction screens are clean and in place? Yes No N/A
 8. Waterflow test valves in closed position? Yes No N/A
 9. Diesel Engine Driven Pumps:
 a. Diesel fuel tank is at least 2/3 full? Yes No N/A
 b. Controller selector switch is in "auto" position? Yes No N/A
 c. Voltage readings for batteries (2) are normal? Charging current readings are normal for batteries? Yes No N/A
 d. Pilot lights for batteries are on or battery failure pilot lights are "off"? Yes No N/A
 e. All alarm pilot lights are "off"? Yes No N/A
 f. Record engine running time from meter: 92.6
 g. Oil level is normal in right-angle gear-drive pumps? Yes No N/A
 h. Crankcase oil level is normal? Yes No N/A
 i. Cooling water level is normal? Yes No N/A
 j. Electrolyte level in batteries is normal? Yes No N/A
 k. Battery terminals free of corrosion? Yes No N/A
 l. Water-jacket heater is operational? Yes No N/A
 10. Circulation relief valve flowing water? Yes No N/A
 11. Pressure relief valves operating with proper pressure downstream while pump is operational? Yes No N/A

B. Testing - Report any failures in the Comments for this form

2. Annual Tests (in addition to above items)

Annual pump test was run using the following method?

Method A Method B Method C

Method A - discharge of water through flow streams. Flow readings taken at each hose stream.

Method B - discharge through bypass flow meter to drain or suction reservoir. Flow readings taken by flow meter.

Method C - discharge through bypass flow meter directly returned to pump suction. Flow readings taken by flow meter.


Note: at least once every three years, method A or B must be used.

Pump Test Results Table

	Churn	50%	100%	Peak Flow
Suction Pressure	10	0	9	6
Discharge Pressure	140	0	125	100
Measured Net Pressure	130.0		116.0	94.0
Net Pressure at Rated RPM	130.0		116.1	94.2
Observed Flow	Not Applicable	0	1512	2270
Flow at Rated RPM	Not Applicable		1512.9	2272.6
Electric Voltage and Current	x	0	x	x
Pump Speed	1760	0	1759	1758
Pump Performance at Rated Flow	Not Applicable	Not Applicable	92.9	Not Applicable

Include 50% flow on the chart?

Yes No



Is the net pressure test result, adjusted for the speed of the pump, at or above 95% of the Rated pressure at the rated flow of the pump?

Yes No

a. Do the remaining values in the results table appear to be acceptable?
b. Diesel engine driven pump ran for 30 min?
c. Circulation and pressure relief valves operated properly during all flow tests?
d. No alarm indicators or other visible abnormalities observed during no-flow test?
e. Suction screens cleaned after flow?

Yes No N/A
 Yes No N/A
 Yes No N/A
 Yes No N/A
 Yes No N/A

f. Automatic transfer switch test:

1. Power failure simulated during peak flow?
2. Connection made to alternate source?
3. After termination of simulated power failure did motor reconnect to normal source?
g. All alarm conditions simulated?
h. All alarms operated?

Yes No N/A
 Yes No N/A
 Yes No N/A
 Yes No N/A
 Yes No N/A

i. Have the gauges, transducers, flow meters and other devices used for measurement calibrated within the past year?

Yes No N/A

j. Electric Fire Pump was manually started? (Do not use the emergency start switch)

Yes No N/A

3. Observations

These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.

Please see the summary section at the top of the form for the comments.


4. Inspector Information:

Test Verification:

Inspected By

Inspector Signature

DAN JOHNSON



Inspector License:

OH FIRE - 54.50.1442

Date of Work

6/12/2025