

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**UNIT HEATER, HOT WATER**

SITE AND BLDG #:	PA027	MECHANIC SIGNATURE: <i>Peter J. Bourke</i>
LOCATION/RM #:	WO#11623 ASSET <u>see notes</u>	DATE: 1/30/2023
		START TIME: 9:30Am FINISH TIME: 12:00PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.			
2	Clean the coils			
3	Comb the fins as needed.			
4	Clean all fans and motors.			
5	Check operation of controls and safeties.			
6	Lubricate as required.			
7	Check all motors, belts, pulleys, shafts, etc. for alignment.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

Assets 3959,3960,3983,4023