

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, HOT WATER

SITE AND BLDG #: PA118

LOCATION/RM #: WO# 14653 ASSET # See notes

MECHANIC
SIGNATURE: *Pat Boardman*

DATE: 1/16/2024

START TIME: 11:00AM

FINISH TIME: 3:00AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel.	●		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		 
TO BE PERFORMED AT EACH INSPECT				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	●		
2	Clean the coils	●		
3	Comb the fins as needed.	●		
4	Clean all fans and motors.	●		
5	Check operation of controls and safeties.	●		
6	Lubricate as required.	●		
7	Check all motors, belts, pulleys, shafts, etc. for alignment.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: Asset 4060,4061,4062,4063,4064,4065,4066,4067,4068,4069,4070,4.