

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: VA010-02

MECHANIC
SIGNATURE: *Dwight Reid*

DATE: 1-2-18

LOCATION/RM #:

START TIME: 9:30AM

FINISH TIME: 10AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA010-02	6611	8071	PM-QT-8066				J-1502000-57 2-pc Overhead Vehicle Exhaust System	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			<i>Vehicle Exhaust</i>	
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			<i>System is</i>	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Start and stop fan with local switch			<i>Out of Service!</i>	
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.				
3	Inspect, adjust belts and pulleys. Replace belt as needed.				
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.			<i>Garage is Not in Use!</i>	
5	Inspect fan for bent blades, unbalance, excessive noise, and vibration.				
6	Clean fan as needed.				

7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.			
8	Repair as needed			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**