

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

Filter Replacement

SITE AND BLDG #: VA001-01

MECHANIC
SIGNATURE:

DATE: 3-26-19

LOCATION/RM #:

START TIME: 9AM

FINISH TIME: 2:30PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA001-01	7918	4680		<i>Cold Point Corp</i>	CEC130B2C900B	11010287	J-1502000-09 2-pc Packaged Terminal AC Filter DecMarJunSep	<i>Classroom</i>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace both internal and external filters as necessary.	✓		
2	Label and Date Filter	✓		
3	Did all High Asset Filters get Changed	✓		
Qty	Size			NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
4	<i>20x25x2</i>	✓		
2	<i>20x20x1</i>	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: GMW **Additional Notes:**

