

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
WATER HEATER

SITE AND BLDG #: VA001-01

MECHANIC
 SIGNATURE: *Andy Bird*

DATE: 5-1-19

LOCATION/RM #:

START TIME:

FINISH TIME: (PM)

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA001-01	8622	7082	PM-QT-6806	<i>Burnham</i>	Alliance SI119	81150297	J-1502000-27 Water Heater cap 119	RM119

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓			
2	Schedule shutdown with operating personnel.	✓			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check valve for full stroke operation in both directions, if applicable.	✓			
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	✓			
3	Clean the coil with vacuum cleaner.		✓	N/A	
4	Comb the fins as needed.		✓	N/A	
5	Clean all fans and motors.		✓	N/A	
6	Check operation of controls and safeties.	✓			

7	Lubricate as required.		✓	✓
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

