



# Closed Loop Water Analysis Report

Account Name: VA-002		Customer Name: Jon Miller				
Sample No: 29705	Date Sampled: 5/2/19	Date Received: 5/6/19		Date Completed: 5/14/19		

	Dual Temp Loop					
Color	Amber					
pH	8.0					
Specific Conductance micromhos, 18°C	3284					
Total Iron as Fe, ppm	2					
Copper as Cu, ppm	0.2					
Sodium Nitrite as NaNO <sub>2</sub> , ppm	N/D					
Molybdenum as Mo, ppm	0.02					
Propylene Glycol Percent by Volume	15*					
Freeze Point, °F	+23					
Reserve Alkalinity	16.7					
Orthophosphate as PO <sub>4</sub> , ppm	1810					

## Additional Comments:

\*Glycol type was based on the refractive index cross-reference with specific gravity of the solution.

N/D = None Detected ----- = Not Tested

Tests Performed By TH

Approved By TB