

Additional Funding Request

Submitted: **07/26/2022**

VA002-HVAC	CSS 1810 WO#18688											
Description of Repairs	S&S will remove & replace the discharge pressure switch. Then, complete a leak check on circuit 1.											
Original SC Investigative Diagnosis	\$450.00											
Diagnosis: Initial Work Order	The FC reported that the HVAC unit is not cooling and the building is very warm.											
Explanation of Additional Costs for Repairs	N/A											
Additional Material Cost to Perform Repairs	Materials: \$403.20 <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; padding: 2px;">ITEM</th> <th style="text-align: left; padding: 2px;">QUANTITY</th> <th style="text-align: left; padding: 2px;">UNIT PRICE</th> <th style="text-align: left; padding: 2px;">TOTAL</th> </tr> </thead> <tbody> <tr> <td style="text-align: left; padding: 2px;">Trane Discharge Pressure Switch</td> <td style="text-align: left; padding: 2px;">1</td> <td style="text-align: left; padding: 2px;">\$403.20</td> <td style="text-align: left; padding: 2px;">\$403.20</td> </tr> </tbody> </table>				ITEM	QUANTITY	UNIT PRICE	TOTAL	Trane Discharge Pressure Switch	1	\$403.20	\$403.20
ITEM	QUANTITY	UNIT PRICE	TOTAL									
Trane Discharge Pressure Switch	1	\$403.20	\$403.20									
Additional Labor Cost to Perform Repairs	Labor: \$1,000 10 hours each/Plumbing Rate \$100.00 per hour = \$1000.00											
Total Cost of Repair	\$1,853.20											