

CMI Management  
 VA 002  
 6901 Telegraph Rd  
 Alexandria VA 22310  
 (202) 437-5119

Recorded By: Marshall Kohne  
 (301) 721-2663  
 mkohne@bondwater.com

### Boiler Room - HVAC Equipment

Test	Dual Temp Loop			
Conductivity (as mmhos)	4160 5000 max			
Molybdate (ppm as Mo)	50 50 - 200			
pH	8.0 8 - 10.5			

#### Dual Temperature Closed Loop

Online 

All readings indicate good levels of protection for closed system. I also changed the filter in the system. I also added 1 gallon of 5001/MO to ensure the system stays in range until my next visit. I also collected a sample of water to be sent to the lab for testing. The salesman will contact management with the results.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.