

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

DDC CONTROLLER

2248,2249,2250
 2251,2252,2253

MECHANIC SIGNATURE: 

DATE: 08-26-22

SITE AND BLDG #: VA006-01

LOCATION/RM #: _____ WO# 18800 ASSET # _____

START TIME: 0900 FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒	☐	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Obtain username and password for login. If not available, contact appropriate company manager to obtain access.	☒	☐	
2	Login into system, check for any alarms currently on system. Make necessary repairs to correct alarms back to normal state.	☒	☐	
3	Check physical condition of the device. Shut off power to the unit.Vacuum any remaining dust. Turn power back on to the unit.	☒	☐	
4	Check all fuses for evidence of heating or weakening.	☒	☐	
5	Check sytem for alarms	☒	☐	
6	Check all plug connections in the panel to ensure the plugs are fully seated.	☒	☐	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes: