

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA006 Date of Visit: 7.1.2020

Contractor Personnel on Site:

- |          |          |
|----------|----------|
| 1. _____ | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

**Service Call Number**

CSS# 22773 WO# 11290

**Description of Repairs**

Removed old Emergency switch for Boilers.  
Ran new wires, Installed new push button E-stop.  
\_\_\_\_\_  
\_\_\_\_\_

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Richard Walker Date: 7.1.2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Don Huson Date: 7.1.2020

Signed: 

E-Mail: \_\_\_\_\_



EMERGENCY  
POWER OFF

PUSH

EMERGENCY  
POWER OFF

