

Tidewater, INC
 VA-006
 1634 Cherry Ave
 Charlottesville VA 22903
 (410) 540-8700

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop			
Conductivity (as mmhos)	167 3500 max			
pH	8.8 8 - 10.5			
Molybdate (ppm as Mo)	30 50 min			

Opening Comment

Performed scheduled service visit.

Hot Water Loop

Offline 

Hot Loop is Offline Corrosion inhibitor residual is slightly low, will add more inhibitor to chemical bypass feeder when system is running for additional corrosion protection in system.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customers wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.