

Tidewater, INC
 VA-006
 1634 Cherry Ave
 Charlottesville VA 22903
 (410) 540-8700

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop			
Conductivity (as mmhos)	186 3500 max			
pH	8.4 8 - 10.5			
Molybdate (ppm as Mo)	10 50 min			

Opening Comment

Performed scheduled service visit.

Hot Water Loop

Online 

Corrosion inhibitor residual is low, added 2# of BOND 2381 and 8 oz of BOND 2005 to chemical bypass feeder for additional corrosion protection. Also replaced chemical feeder gasket at no extra charge.

Please check make up water backflow preventer as it is actively leaking.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its Insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.