

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA0006

Date of Visit: 9/5/19

Contractor Personnel on Site:

1. Nicholas LoRusso

4. _____

2. Kenneth Stahl

5. _____

3. _____

6. _____

Service Calls – Service Call Number and Description

1. HySecurity Gate Operator

2. HySecurity IS

3. serial #: 011400-1615-222

Found corroded terminations on connections Gate opens intermittently.

Repairs: Reterminated all corroded terminations, made photocye adjustments, tested gate from CTC Readers CERTIFICATION OF WORK and Intercom solution multiple times. Gate is now in operable condition and fully function -al.

To be signed by the Contractor:

Print Name: Nick LoRusso

Date: 9/5/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Jamie Watson

Date: 20190905

Signed: 

E-Mail: _____