

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
EXHAUST FANS

SITE AND BLDG #: VA009-01

MECHANIC  
SIGNATURE: *Tu L*

DATE: *6/4/19*

LOCATION/RM #:

START TIME: *9AM*

FINISH TIME: *10AM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA009-01	8900	1358					J-1502000-07 1-pc Exhaust Fan	<i>Kitchen</i>
VA009-01	8900	1360					J-1502000-07 1-pc Exhaust Fan	<i>Kitchen</i>
VA009-01	8900	1361		<i>Nutone</i>			J-1502000-07 2-pc Bathroom Exhaust Fan	<i>bathroom</i>
VA009-01	8900	1362					J-1502000-07 1-pc Exhaust Fan	<i>mech room</i>
VA009-01	8900	1363					J-1502000-07 1-pc Exhaust Fan	<i>mech room</i>
VA009-01	8900	1364					J-1502000-07 1-pc Exhaust Fan	<i>mech room</i>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Schedule shutdown with operating personnel, as needed.			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				

1	Clean unit, especially fan blades.			
2	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multiple belts should be replaced with matched sets.			
3	Perform required lubrication and remove old or excess lubricant.			
4	Clean motor with vacuum or low pressure dry air (less than 40 psi). Check for obstructions in motor cooling and air flow.			
5	Check structural members, vibration eliminators, and flexible connections. Check fan housing to ensure there is no damage and the housing is tight.			
6	Start unit and check for vibration and noise.			
7	Remove all trash and debris.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

