

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATE KEYPAD / CARD READER

SITE AND BLDG #: VA009-01

MECHANIC
 SIGNATURE: *Geo. E. G.*

23 JUL 19

DATE: *Geo*

LOCATION/RM #:

START TIME: *9:00 A* FINISH TIME: *10:00 A*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA009-01	9561	2281					J-1502000-53 2-pc Auto Access Control	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If applicable, test the controls for communications to the monitoring center. Inspect key pad for sticking keys and LED lights proper operation.		✓	<i>N/A</i>
2	Check power supplies. Clean keys and pad with a quick dry electrical cleaner. Wipe unit down		✓	<i>N/A</i>
3	Inspect and test the operation of device. -Observe unit in use			
4	Ensure proper protection of all visible wiring and conduits	✓		

5	Verify that no compromise to devices has occurred (compromise of devices could be from building alterations, partitions, furniture or other obstacles) Any deficiencies found open a CM work order in Maximo and quote will be provided for CM repairs. Notate in note Column	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
---	---	-------------------------------------	--------------------------	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

