

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
LIGHTING, OUTSIDE

SITE AND BLDG #: VA009-01

MECHANIC  
SIGNATURE: *Tn L*

DATE: 3/11/19

LOCATION/RM #: exterior of building

START TIME: 9 AM

FINISH TIME: 10 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA009-01	7868	2276					J-1502000-44 2-pc Four Light, Pole Mounted	<u>POV</u>
VA009-01	7868	2277					J-1502000-44 2-pc Single Light, Pole Mounted	<u>SIDES</u>
VA009-01	7868	2278					J-1502000-44 2-pc Double Light, Pole Mounted	<u>SIDES</u>
VA009-01	7868	2279					J-1502000-44 3-pc Three Light, Pole Mounted	<u>BACK of</u>

PROPERTY

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Schedule and coordinate work with operating personnel.			
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.			
2	Inspect visual condition of wiring. Look for evidence of overheating.			
3	Check for proper light operation.			
4	Test operation of automatic switches/ time clock/ photocells if applicable.			
5	Inspect light pole and mounting devices for deficiencies.			

6	For any noted deficiency, takes pictures and open corrective maintenance ticket.			
---	--	--	--	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

