



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Christiansburg, VA

Falmouth, VA • Lynchburg, VA • Richmond, VA • Greensboro, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address		Site Address
Customer: INTERNATIONAL SUPPORT GROUP		Customer: ISG USARC VA009 SUFFOLK
Address: 9000 SHERIDAN ST		3502 BENNETT CREEK PARK ROAD
PEMBROKE PINES FL 33024		SUFFOLK VA 23345
Phone: 954-900-1095		Phone: 8045855211
Service Call #: COM0118095		Call Type: COM-PLMB

Service Requested

CSS 21282 WO 10641 NTE 450.00 Maintain by repairing the hot water tank that is leaking in the supply caging area.

09/30/19BW: EMAILED LOCY TO SEE IF WE ARE RUNNING THIS CALL OR HOW TO PROCEED

10/04/19BW: RESCH'D 10/08

10/10/19BW: CALLED CORY TO ATTACH COW AND QUOTE

10/16/19: JLU QUOTE SUBMITTED

10/21/19BW: QUOTE APPROVAL 1734.23 / 5 HRS

DESCRIPTION OF EQUIPMENT:

CSS-21282/Water heater repair

DESCRIPTION OF REPAIRS:

Moore's is proposing to make repairs to the leaking water heater on site. The leak is coming from the t&p relief valve. Will drain the water heater to replace the valve. Once new valve is installed, will fill water heater back up. Will then test for any leaks, and then turn heater back on.

10/22/19BW: ORDER MATERIALS FROM FERG - DUSTY - WILL BE READY FOR PICK UP 10/23 BY EOB

10/29/19 AK: SCHEDULED FOR 11/5

11/11/19BW: RESCHD 11/12

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
UNIT LEAKING	CORYSANDLI				
UNIT LEAKING	MATTFRASER				

Tech Notes

Tech: CORY SANDLIN, Date: 9/29/19 10:23 PM - STARTED DRIVING TO SITE. GOT A CALL WHILE ON THE WAY TO THE SITE THAT THE PERSON ON SITE THAT WOULD GIVE ME ACCESS TO SITE WAS OFF UNTIL MONDAY. COULD NOT GO TO CALL DUE TO THIS INFORMATION.

Tech: CORY SANDLIN, Date: 10/8/19 7:48 PM - Drove to site. Met Angela on site. Looked at the water heater in the storage room. Found the t&p valve leaking. Will have to put quote in to replace t&p valve.

Tech: CORY SANDLIN, Date: 11/12/19 10:58 AM - Drove to site. Met Angela. Drained heater. Replaced old dripping t&p valve with new valve. Filled heater back up and bled water out of lines. Turned power back onto heater. There are no leaks at this time.

Labor

Date	Technician	Description	Hours
9/27/2019	CORY SANDLIN	COMMERCIAL TRAVEL TIME	1.50
10/8/2019	CORY SANDLIN	COMMERCIAL TRAVEL TIME	4.00
10/8/2019	CORY SANDLIN	REGULAR PLUMBING LABOR	1.00
11/12/2019	CORY SANDLIN	COMMERCIAL TRAVEL TIME	2.00
11/12/2019	CORY SANDLIN	REGULAR PLUMBING LABOR	2.25

Materials

Date	Part Number	Description	Quantity
9/29/2019	CMISCX-TRUCK CHARGE	TRUCK CHARGE	1.000
9/29/2019	CMISCX-TRIP CHARGE	TRIP CHARGE	1.000
9/29/2019	CMISCX-QUOTED GS AMOUNT	QUOTED AMOUNT SUBMITTED FOR THIS GENERAL SERVICE JOB	11.500

Signed By		Signature		Date	
------------------	--	------------------	--	-------------	--