

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
WATER HEATER

SITE AND BLDG #: VA010-01

MECHANIC

SIGNATURE:

Andy Bird

DATE: 5-6-19

LOCATION/RM #:

START TIME:

9AM

FINISH TIME:

10:30AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA010-01	8651	6954	PM-QT-6836	Xuvien	NR-180A	84954 99543 4	J-1502000-27 1-pc Water Heater	Mech JRM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.	✓		
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.		✓	N/A
3	Clean the coil with vacuum cleaner.		✓	N/A
4	Comb the fins as needed.		✓	N/A
5	Clean all fans and motors.	✓		
6	Check operation of controls and safeties.	✓		

7	Lubricate as required.		✓	N/A
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

