

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: _____ Date of Visit: _____

Contractor Personnel on Site:

- | | |
|----------|----------|
| 1. _____ | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: _____ Date: _____

Signed:  _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____

Signed: _____

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST COOLING TOWER

SITE AND BLDG #: VA011

190918-211

MECHANIC
SIGNATURE:


DATE: 04-08-22

LOCATION/RM #:

WO# 16784

ASSET #

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
Cooling Tower				
1	Inspect Tower VFD - Record any display alarms	✓		
2	Clean cooling tower fills -Honeycomb appearance	✓		
3	Inspect sump water level controls - level float or level sensor	✓		
4	Check electrical wiring and tighten loose connections. Check fused disconnect switches for condition and operation, contactors -VFD for Fan	✓		
5	Check Fan motor mounting for tightness.	✓		
6	Inspect fan drive belts -adjust or replace as needed -1/2" belt deflection	✓		
7	Check fan or blower for bent or damaged blades and imbalance.	✓		
8	Lubricate shaft and motor bearings on fans and remove old or excess lubricant, if applicable.	✓		
9	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multi-belt drives should be replaced with matched sets.	✓		
10	Drain -Flush and clean sump pan for tower -Refill sump after cleaning is completed -	✓		
11	Inspect plumbing, valves and flanges for leaks and correct as needed.	✓		
12	Record AMP draw for Main drive fan motor	✓		L1 _____ L2 _____ L3 _____
13	Record AMP draw for Sump to top of tower circulation pump	✓		L1 _____ L2 _____ L3 _____
14	Check bearings for vibrations or unusual noises.	✓		
15	Inspect contactors for Fan motor and sump Motor	✓		
16	Report any rust or corrosion issues -Open CM	✓		

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
17	Inspect heat trace system on cooling tower line sets -IF applicable	✓		
18	Confirm Chemical water treatment system is operating properly	✓		Located in main plant -Checked monthly by Bond Water Treatment
19	Record tower water conductivity level from controller in plant	✓		
20	Report and deficiencies and open a CM	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes: