

### Over and Above Estimate

**Region:** 5

**Location:** VA011

**CSS #:** 27507

**Asset #:**

**Maximo Work Order No.:** 13159

**Date Issued:** 11/20/2020

**Original Description:** Upon inspection found unit to have a Glycol Leak and unit is out on low pressure.

**Repair Needed:** Moore's will valve off system, recover glycol, repair leaking fittings, put back together and replenish glycol. We will also recover refrigerant, pressurize system and check for leaks, and make necessary repairs. (This quote covers minor brazing, no replacement of parts.)

#### Non Pre-Priced Estimate:

Quantity	Line Item Number	Description	Labor Hours	Unit	Labor	Materials	Equipment	Total
	N/A	Materials (see detail on Moore's quote)				\$821.55		\$795.00
	N/A	Labor (see detail on Moore's quote)			\$2,880.00			\$2,880.00
		Admin hours	2		\$80.00			\$160.00

*Note: RS Means (Pre-Priced) not used in compiling this estimate.*

*Note: Subcontractor quote attached.*

#### Estimate Summary:

Labor Hours	Labor Cost	Material Cost	-PM COST	Total Cost	CE Factor	Total Estimate
26	\$3,040.00	\$795.00		\$3,835.00	100%	\$3,835.00