

Over and Above Estimate

Region: 5

Location: VA011

CSS #: 27507

Asset #:

Maximo Work Order No.: 13159

Date Issued: 11/20/2020

Original Description: Upon inspection found unit to have a Glycol Leak and unit is out on low pressure.

Repair Needed: Moore's will valve off system, recover glycol, repair leaking fittings, put back together and replenish glycol. We will also recover refrigerant, pressurize system and check for leaks, and make necessary repairs. (This quote covers minor brazing, no replacement of parts.)

Non Pre-Priced Estimate:

Quantity	Line Item Number	Description	Labor Hours	Unit	Labor	Materials	Equipment	Total
	N/A	Materials (see detail on Moore's quote)				\$795.00		\$795.00
	N/A	Labor (see detail on Moore's quote)			\$1,800.00			1,80000
		Admin hours	2		\$80.00			\$160.00

Note: RS Means (Pre-Priced) not used in compiling this estimate.

Note: Subcontractor quote attached.

Estimate Summary:

Labor Hours	Labor Cost	Material Cost	-PM COST	Total Cost	CE Factor	Total Estimate
26	\$1,960.00	\$795.00		\$2,755.00	100%	\$2,755.00



P.O. Box 119 • Altavista, VA 24517 • 24 Hour Service: 800.789.7199 • Fax: 888.722.2712 • MooresElectric.com

Proposal

November 24, 2020

Quotes are valid for 30 days.

USARC - VA # 011
1821 Industry Street
Culpeper, VA 22701
Email tina.lee@tideh2o.net

Contact Name Tina Lee & Adam Colopy
Telephone 0.00
Cell Phone 614-623-9569
Fax Number 0.00

DESCRIPTION OF EQUIPMENT:

ClimateMaster WSHP#7 M: GCH024BGM30CRSS S: L13985772

DESCRIPTION OF PROBLEM:

Upon inspection found unit to have a Glycol Leak and unit is out on low pressure.

DESCRIPTION OF REPAIRS:

Moore's will valve off system, recover glycol, repair leaking fittings, put back together and replenish glycol. We will also recover refrigerant, pressurize system and check for leaks, and make necessary repairs. (This quote covers minor brazing, no replacement of parts.)

MATERIAL, EQUIP OR PARTS

		Quantity	Sell price
Environmental Fee		1.00	\$ 250.00
Pump Fee		1.00	\$ 125.00
TORCH-15% /NITROGEN/VACUUM/RECOVERY FEE		1.00	\$ 195.00
Refrigerant (R22)		3.00	\$ 225.00
	Material Total		\$ 795.00

LABOR ITEMIZED

			Labor
Labor - Incurred	3	\$ 120.00	\$ 360.00
Labor - One Man	12	\$ 120.00	\$ 1,440.00
Labor - Second Man	0	\$ 120.00	\$ -
		Labor Total	\$ 1,800.00

Thank you for your business. If you have any questions or concerns, please feel free to contact us via telephone or quotes@mooreselectric.com

Materials \$ 795.00
Labor \$ 1,800.00

TOTAL \$ 2,595.00

*This does include
original call cost.*

Robert Lowery, Changeout Estimator 434-309-2591
Ian Harris, Estimator 434-309-2497
James Davis, Estimator 434-309-2568
Marvin Slaughter, Estimator 434-369-3514
Jared Underwood, Estimator 434-306-2446

Approved by: _____

In consideration of Moore's Electrical & Mechanical extending credit to the above applicant, the undersigned hereby personally guarantees unconditionally and irrevocably. The compliance of all terms of the application and agreement, including the payment of any sums within the net terms agreed upon between the customer and Moore's, plus any additional costs such as a 1.5% monthly interest charge starting once an invoice becomes 30 days past due, service charges, legal fees and any means taken in order to collect debt. If it is deemed necessary to litigate, it is agreed that the County or District Court of Campbell County, Virginia shall be the venue of any suit. This guarantee shall remain in full force unless and until notice in writing is sent certified mail and received by Moore's Electrical & Mechanical. Said notice cannot be within 14 days of this signed agreement. Initial service request ran with a Not to Exceed amount of \$500.00 (five hundred dollars).



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address		Site Address
Customer:	TIDEWATER, INC	Customer: USARC VA011 CULPEPER
Address:	6625 SELNICK DRIVE ELKRIDGE MD 21075	Address: 1821 INDUSTRY STREET CULPEPER VA 22701
Phone:	614-623-9569	Phone: 614-623-9569
Service Call #:	COM0142367	Call Type: COM-HVAC

Service Requested

WO: WO 13159 | We have a new request that came in for one of our sites VA011 in Virginia and I was wondering if you would be able to head out to the site and provide us with a quote for repair?
SOW: WSHP#7 Unit has glycol leak and locked out on low pressure (Freon leak) CSS# 27507

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
UNIT LEAKING	BRIASCHAMP	WSHP#7 GCH024BGM30CRSS	CLIMATEMASTER	L13985772	

Tech Notes

Tech: BRIAN SCHAMP, Date: 11/4/20 12:00 PM - BRIAN SCHAMP: Site Start - 11/4/2020 12:00 PM
- ON SITE CHECKED IN WITH CHRIS. FOUND WSHP#7 WITH GLYCOL AND REFRIGERANT LEAK . WILL QUOTE TO REPAIR GLYCOL FITTING AND LEAK
SEARCH UNIT. SEE K2 QOUTE FOR SAME ISSUE

Labor

Date	Technician	Description	Hours
11/4/2020	BRIAN SCHAMP	REGULAR HVACR LABOR	2.00
11/4/2020	BRIAN SCHAMP	COMMERCIAL TRAVEL TIME	1.00

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	COVID	Signature		Date	11/4/2020
-----------	-------	-----------	-------------------------------------------------------------------------------------	------	-----------