

CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA011 Date of Visit: 8/7/2020

Contractor Personnel on Site:

1. Marshall Koline
2. _____
3. _____
4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. BOND MONTHLY WATER TREATMENT WO 11942 ASSET 190918-243
2. _____ WO 12551
3. _____ ASSET 190918-243
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Chris Chipp Date: 8-7-20

Signed: Chris Chipp

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Marshall Koline Date: 8/7/2020

Signed: Marshall Koline

E-Mail: _____

Tidewater, INC
 VA-011
 1821 Industry St.
 Culpeper VA 22701
 (410) 540-8700

Recorded By: Marshall Kohne
 (301) 721-2663
 mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	7005 5000 max			
pH	10.2 8 - 10.5			
Molybdate (ppm as Mo)	200 50 - 200			

Closed Loop

Online 

Conductivity is elevated due to the presence of glycol as well as MO, nothing to be concerned with. Once the system is running and cycles all readings will be in desired ranges.