

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA011

Date of Visit: 10/30/2020

Contractor Personnel on Site:

1. Marshall Kohne
2. _____

3. _____
4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. BOND MONTHLY WATER TREATMENT WO 11942 ASSET 190918-212 12859
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Marshall Kohne Date: 10/30/2020
Signed: Marshall Kohne

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Chris Chipp Date: 10/30/2020
Signed: Chris Chipp

E-Mail: _____

Tidewater, INC
 VA-011
 1821 Industry St.
 Culpeper VA 22701
 (410) 540-8700

Recorded By: Marshall Kohne
 (301) 721-2663
 mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	2908 5000 max			
pH	9.2 8 - 10.5			
Molybdate (ppm as Mo)	50 50 - 200			

Closed Loop

Online 

All readings indicate good levels of protection for closed system. System is idle. Five gallons of Glycol have been added to the system since my last visit. I also collected a water sample to be sent to the lab for analysis.