

Tidewater, INC
 VA-011
 1821 Industry St.
 Culpeper VA 22701
 (410) 540-8700

Recorded By: Marshall Kohne
 (301) 721-2663
 mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	4525 5000 max			
pH	8.8 8 - 10.5			
Molybdate (ppm as Mo)	10 50 - 200			

Closed Loop

Online 

System still has visible leaks. Once leaks are fixed I will retreat the system with chemical. Leaks in the system will cause more rapid corrosion as well as higher utility bills and Glycol usage.