

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DOOR KEYPAD / CARD READER

SITE AND BLDG #: VA033-01

**MECHANIC
SIGNATURE:** *Mike Merchant*

DATE: 8 Jul 19

START TIME: 12:45 PM

FINISH TIME: 1:30 PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA033-01	9886	7884					J-1502000-54 1-pc Key Card Scanner	
VA033-01	9886	7885					J-1502000-54 1-pc Key Card Scanner	
VA033-01	9886	7886					J-1502000-54 1-pc Key Card Scanner	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		

TO BE PERFORMED AT EACH INSPECTION SERVICE

1	If applicable, test the controls for communications to the monitoring center. Inspect key pad for sticking keys and LED lights proper operation.	✓	Completed. See below
2	Check power supplies. Clean keys and pad with a quick dry electrical cleaner. Wipe unit down	✓	
3	Inspect and test the operation of device. -Observe unit in use	✓	
4	Ensure proper protection of all visible wiring and conduits	✓	

5	Verify that no compromise to devices has occurred (compromise of devices could be from building alterations, partitions, furniture or other obstacles) Any deficiencies found open a CM work order in Maximo and quote will be provided for CM repairs. Notate in note Column	<input checked="" type="checkbox"/>	
---	---	-------------------------------------	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker Additional Notes: