

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: VA033-02

MECHANIC
SIGNATURE: *Chucky Bird*

DATE: 3-6-19

LOCATION/RM #:

START TIME: 1PM

FINISH TIME: 3PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA033-02	7558	7420		<i>N/A</i>			J-1502000-45 1-pc Double Light, Pole Mounted Aluminum LED	<i>Motor pool</i>
VA033-02	7558	7427		<i>N/A</i>			J-1502000-45 1-pc Flood Light, Pole Mounted Aluminum LED	<i>Motor pool</i>
VA033-02	7558	7476		<i>N/A</i>			J-1502000-45 9-pc Flood Light, Pole Mounted Wood LED	<i>Perimeter</i>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>		
2	Schedule and coordinate work with operating personnel.	<input checked="" type="checkbox"/>		
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	<input checked="" type="checkbox"/>		
2	Inspect visual condition of wiring. Look for evidence of overheating.	<input checked="" type="checkbox"/>		
3	Check for proper light operation.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<i>N/A</i>
4	Test operation of automatic switches/ time clock/ photocells if applicable.		<input checked="" type="checkbox"/>	<i>N/A</i>

5	Inspect light pole and mounting devices for deficiencies.	<input checked="" type="checkbox"/>		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

