

Date: 12-18-25

Region: 4C

FEMS/CSS No.: 3433088

FAC ID: VA033

Maximo WO No.: 20924

Asset #:

Priority: 1



Original Work Request:

Boilers in hard lock out, discovered during boiler certification inspection. Tech unable to get it running, will need service ticket to repair as there is no heat in the Training Bldg.

Description of Repairs Needed:

Proposal for responding to emergency service call on Triad boiler. Reset the boiler and pulled oil thru the boiler and verified for proper operation

Labor:

	Labor Hrs	Labor Rate	Total
Tech (1)	8.1	\$ 140.00	\$ 1,136.00
Trip Charge	1	\$ 131.25	\$ 131.25
			\$ -

Material List:

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	
		\$ -	
		\$ -	
		\$ -	
		\$ -	

Equipment List:

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$1,267.25	\$0.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$1,267.25	\$152.07	\$76.04	\$1,495.36