

**Over and Above Estimate**

**Region:** 4

**Location:** VA033

**CSS #:** 15179

**Maximo Work Order No.:** 5714

**Asset#:** NA

**Date Issued:** 8/20/18

**Original Description:** Diagnose the Fuel Oil Control System

**Diagnosis:**

Moore's is proposing to have a Veeder Root distributor to come to site to remove and install the new fuel oil control monitor. Start, test, and ensure proper operation of the system.

**Non Pre-Priced Estimate:**

Quantity	Line Item Number	Description	Labor Hours	Unit	Labor	Materials	Equipment	Total
1		Veeder Root Control w/ Printer				\$2,721.13		\$2,721.13
1		Enhancement Software Module				\$411.73		\$411.73
1		Veeder Root Tech Labor				\$841.18		\$841.18
1		VA Tax				\$138.37		\$138.37

*Note: RS Means (Pre-Priced) not used in compiling this estimate.*

*Note: Subcontractor quote attached.*

**Estimate Summary:**

Labor Hours	Labor Cost	Material Cost	Equipment Cost	Total Cost	CE Factor	Total Estimate
		\$4,112.41		\$4,112.41	102%	\$4,194.67

**Please see attached estimate**

**Note:**



P.O. Box 119 • Altavista, VA 24517 • 24 Hour Service: 800.789.7199 • Fax: 888.722.2712 • MooresElectric.com

## Proposal

November 28, 2018

Quotes are valid for 30 days.

USARC VA033 Galax  
125 A Armory Road  
Galax, VA 24333  
Email

[tcaig@internationalsupportgroup.com](mailto:tcaig@internationalsupportgroup.com) Fax Number

Contact Name Troy Craig  
Telephone 804-585-5211  
Cell Phone 954-900-1095  
Fax Number 0.00

### DESCRIPTION OF EQUIPMENT:

FUEL OIL CONTROL MONITOR FOR THE BOILER  
VEEDER ROOT MODEL TLS-300C,  
S/N E10169398805002

### DESCRIPTION OF PROBLEM:

While onsite, our technician Sean O'Neill found the fuel oil control monitor listed above bad and in need of replacement. Recommend replacing the fuel oil control monitor to ensure proper operation of the system.

### DESCRIPTION OF REPAIRS:

Moore's is proposing to have a Veeder Root distributor to come to site to remove and install the new fuel oil control monitor. Start, test, and ensure proper operation of the system.

Note: PER THE VEEDOR ROOT THE FUEL OIL CONTROL MONITOR HAS TO BE INSTALLED BY ONE OF THEIR CERTIFIED TECHNICIAN OR THE WARRANTY IS VOID ON THE NEW CONTROL. THIS QUOTE IS FOR VEEDER ROOTS TECH TO INSTALL THE NEW CONTROL AND TO PROGRAM IT TO WORK WITH THE EXISTING SYSTEM.

### MATERIAL, EQUIP OR PARTS

	Quantity	Sell price
Veeder Root Control With Printer	1.00	\$ 2,721.13
Enhancement Software Module	1.00	\$ 411.73
Veeder Root Tech Labor	1.00	\$ 841.18
<b>Material Total</b>	<b>\$</b>	<b>3,974.04</b>

### LABOR ITEMIZED

Labor
\$ 120.00
<b>Labor Total</b> \$ -

Thank you for your business. If you have any questions or concerns, please feel free to contact us via telephone or [quotes@mooreselectric.com](mailto:quotes@mooreselectric.com)

<b>Materials</b>	<b>\$</b>	<b>3,974.04</b>
<b>Tax</b>	<b>\$</b>	<b>138.37</b>
<b>TOTAL</b>	<b>\$</b>	<b>4,112.41</b>

*This does not include original call cost.*

Robert Lowery, Changeout Estimator 434-309-2591  
Amy Hockaday, Estimator 434-309-2569  
James Davis, Estimator 434-309-2568  
Adam Barker, Estimator 434-369-3514  
Jared Underwood, Estimator 434-306-2446

Approved by: \_\_\_\_\_

### Standard Terms and Conditions

Payments past 30 days are subject to 1.5% monthly service charge on unpaid balance. Additional charges for payments made through credit cards may apply. Late payments sent to collections or legal process the purchaser agrees to pay all costs, expenses, and reasonable attorney fees.

# Agreement

to

**Provide Equipment and Installation for 1 (one)  
TLS-300 Veeder Root System**

for

**Moore's Electrical  
Altavista, Virginia**

***especially prepared***

for

**Moore's Electrical  
C/O Mr. James Davis**

by



***Four Star Petroleum Services, Inc.***

**1119 Beaumont Road**

**Roanoke, VA 24019**

**Phone 540-563-1022**

**Fax 540-362-1820**

**Virginia Contractors License # 2705 047793-A**

Agreement # FC-18-170

Moore's Electrical  
C/O Mr. James Davis  
1305 South Main Street  
Altavista, Virginia 24517

Site Address:  
International Support Group  
125 Armory Road  
Galax, Virginia 24333

Dear Mr. Davis,

Thank you for allowing Four Star Petroleum Services, Inc. the opportunity to present you with our agreement to provide and install a new Veeder Root TLS-300 for International Support Group located at 125 Armory Road in Galax, Virginia 24333.

**The following is an itemized list of proposed equipment:**

QTY	PART#	EQUIPMENT DESCRIPTION	EACH	EXTEND
<b>CONSOLE EQUIPMENT</b>				
1	848590-521	VEEDER ROOT TLS-350 WITH PRINTER	\$2,267.61	\$2,267.61
1	330161-001	ENHANCEMENT SOFTWARE MODULE	\$343.11	\$343.11
<b>TOTAL EQUIPMENT COST (WITHOUT VIRGINIA SALES TAX)</b>				<b>\$2,610.72</b>
VIRGINIA SALES TAX AT 5.3%				<b>\$138.37</b>
<b>TOTAL COST FOR EQUIPMENT INSTALLATION</b>				<b><u>\$841.18</u></b>
<b>TOTAL COST OF AGREEMENT</b>				<b>\$3,590.27</b>

Initial \_\_\_\_\_ / \_\_\_\_\_

**OWNER PROVIDED SERVICES, MATERIALS AND NOTIFICATIONS:**

**The existing electrical service must be adequate to support the equipment installation.**

**Obtain permits, if needed, and invoice the cost of the permit, professional and / or engineering fees and the labor to procure the permits to the owner (labor cost of \$40.00 per hour and mileage at \$0.65 per mile).**

**Scope of Work (Installation of New Equipment):**

- Remove 1 (one) Veeder Root TLS-300 console and discard.
- Install 1 (one) Veeder Root TLS-300 console with printer where the existing tank monitor was located.
- Make all electrical connections at the console area using the existing wiring and probes.
- Program the TLS-300 system console using existing wiring.
- Train the personnel on proper operation of the new equipment.
- Dispose of debris from job site (trash, equipment containers, etc.).

**WARRANTY DISCLAIMER AND LIMITATION OF LIABILITY:** FOUR STAR PETROLEUM SERVICES MAKES NO WARRANTIES OF ANY KIND WITH RESPECT TO ANY EQUIPMENT FURNISHED HEREUNDER. ANY WARRANTIES ARE THOSE OF THE MANUFACTURER ONLY. FOUR STAR PETROLEUM SERVICES SPECIFICALLY DISCLAIMS THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. UNDER NO CIRCUMSTANCES SHALL FOUR STAR PETROLEUM SERVICES BE LIABLE TO YOU FOR ANY INCIDENTAL, CONSEQUENTIAL, SPECIAL OR PUNITIVE DAMAGES OF ANY KIND TO INCLUDE, BUT NOT LIMITED TO, LOSS OF PROFIT, LOSS OF BUSINESS, LOSS OF PRODUCT OR ANY OTHER DAMAGES.

Initial \_\_\_\_\_ / \_\_\_\_\_

**INSTALLATION WARRANTY:** FOUR STAR PETROLEUM SERVICES WILL WARRANT OUR INSTALLATION WORK AGAINST DEFECTS IN WORKMANSHIP FOR A PERIOD OF 1 (ONE) YEAR FROM THE DATE OF COMPLETION. IN THE EVENT OF A DEFECT IN WORKMANSHIP OR CONCRETE, YOU MUST NOTIFY FOUR STAR PETROLEUM SERVICES IN WRITING WITHIN THE WARRANTY PERIOD. FOUR STAR PETROLEUM'S SOLE OBLIGATION IS TO REPAIR THE PARTICULAR DEFECT. FOUR STAR PETROLEUM SERVICES SHALL NOT BE LIABLE TO YOU FOR ANY INCIDENTAL, CONSEQUENTIAL, SPECIAL OR PUNITIVE DAMAGES OF ANY KIND TO INCLUDE, BUT NOT LIMITED TO, LOSS OF PROFIT, LOSS OF BUSINESS, LOSS OF PRODUCT OR ANY OTHER DAMAGES.

**Indemnification:** You shall indemnify, defend, and hold harmless Four Star Petroleum Services from and against any and all claims, demands, damages, losses, and costs of any kind or nature, including attorney's fees, as a result of your use of the equipment installed hereunder, except as may be caused by the negligence of Four Star Petroleum Services.

**Terms and Conditions:**

Our agreement is contingent upon providing installation as proposed above and is based on the equipment specifications, electrical and proposed location of said components. Any owner change in the scope of work, as presented, will cause an adjustment in the price.

This project is proposed to be performed in 1 (one) mobilization. If delays (or additional mobilization expenses) are caused by the owner, additional charges will result.

**Payments Terms:**

The agreement cost of \$3,590.27 (three thousand five hundred ninety dollars and twenty-seven cents) is due upon completion in net 10 (ten) days from the date of the invoice.

If payments are not made when due, the owner will pay interest at the rate of 2% (two percent) per month, plus all costs of collection, including any attorney's fees incurred by Four Star Petroleum Services.

**No federal, state or DEQ paper work will be released until all payments have been made in full.**

Initial \_\_\_\_\_ / \_\_\_\_\_

Any lawsuits arising hereunder shall be brought only in the Circuit Court of the City of Roanoke, Virginia or in the United States District Court for the Western District of Virginia, Roanoke Division. The parties consent to the jurisdiction of such courts and waive all objections to venue in such courts. The laws of the Commonwealth of Virginia shall govern this agreement

Your signature certifies your acceptance of our agreement, including our terms and conditions for payment.

This agreement is good for 30 (thirty) days from the agreement date and must be signed by a representative of Four Star Petroleum in order to constitute a binding contract.

If our agreement is acceptable to you, please initial each page, sign below and forward to us at your earliest convenience. We will sign and return a copy for your records. Again, we thank you for this opportunity and look forward to working with you on this project.



**Agreement FC-18-170**

**ACCEPTANCE:** I am authorized to and do hereby accept this agreement on behalf of purchaser.

**ACCEPTANCE:**  
**Four Star Petroleum Services, Inc.**

Signature

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Title \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Date \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Phone # \_\_\_\_\_

**(540) 563-1022**  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Fax # \_\_\_\_\_

**(540) 362-1820**  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**CERTIFICATION OF WORK**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: 8233822 Date of Visit: 8-22-18

Contractor Personnel on Site:

1. Sean O'Neill 2. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# COM0089664

**Service Calls** - Service Call Number and Description

1. CSS# 15179 - Boiler Fuel level Alarm (disable)
2. CSS# \_\_\_\_\_
3. CSS# \_\_\_\_\_

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Sean O'Neill Date: 8-22-18

Signed: SO'Neill

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Bryan Beard WS09 Date: 22 Aug 2018

Signed: B. Beard

E-Mail: bryan.d.beard.civ@mail.mil



**VEEDER-ROOT**

ALARM



WARNING



POWER



ALARM TEST  
BACKUP  
FUNCTION  
PRINT  
CHANGE  
STEP  
PAPER FEED  
ENTER  
TANK SENSOR

QZ 1 ABC 2 DEF 3  
GHI 4 JKL 5 MNO 6  
PRS 7 TUV 8 WXY 9  
↔ 0 ↵ .

**TLS-300e**

SYSTEM STATUS REPORT  
SYSTEM SELF TEST ALARM  
T HIGH WATER ALARM  
L LOW FUEL ALARM  
L LOW TANK TONE ALARM

SYSTEM STATUS REPORT  
SYSTEM SELF TEST ALARM  
T HIGH WATER ALARM  
L LOW FUEL ALARM  
L LOW TANK TONE ALARM