

**CERTIFICATION OF WORK**  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA039 Date of Visit: 1/15/2019

Contractor Personnel on Site:

1. Howard Floyd 2. \_\_\_\_\_

**Work Performed:** Found Boiler #4 'low water cut-off' (LWCO) failed open. Verified a strong water flow in the boiler. Jumped out the safety and checked the boiler operation until it satisfied the temperature controller to verify correct operation. Boiler #3 is the only operational boiler at this present time. Boiler #1 is ready to go but being held off on Energy Mgmt. control. Boiler #2 already has a repair proposal submitted. Proposal submitted for Boiler #4.

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# COM0098875

**Service Calls** – Service Call Number and Description

1. CSS# 8233824 \_\_\_\_\_
2. CSS# \_\_\_\_\_
3. CSS# \_\_\_\_\_

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Howard Floyd Date: 1/15/2019

Signed: \*<SIGNED>\*Floyd, Howard

E-Mail: [hfloyd@mooreselectric.com](mailto:hfloyd@mooreselectric.com)

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: GS09 McTamaney, STStephanie Date: 20190115

Signed: \*<SIGNED>\* McTamaney, Stephanie 8608

E-Mail: [stephanie.n.mctamaney.civ@mail.mil](mailto:stephanie.n.mctamaney.civ@mail.mil)

### CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA039 Date of Visit: 02/12/2019

Contractor Personnel on Site:

1. Howard Floyd 2. \_\_\_\_\_

**Work Performed:** Isolated boiler #4, removed/replaced low water cut-off, started up and checked operation. Obtained pictures of the temperatures.

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# 8233824

**Service Calls** – Service Call Number and Description

1. CSS# 17215

2. CSS# \_\_\_\_\_

3. CSS# \_\_\_\_\_

### CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Howard Floyd Date: 02/12/2019

Signed: Howard Floyd

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Stephanie McManamy GSO9 Date: 2019/02/12

Signed: Stephanie McManamy

E-Mail: Stephanie.n.mcmanamy.civ@mail.mil



3889

RESET

Mode

Step

Store

+

DELETA  
RESET



3889 (--- is the measured value)

Prestige  
Digital Display

3140

RESET



TriangleTube

3140

PARA

INFO

1180

Measured Supply  
Water Temperature

2150

Measured Return  
Water Temperature

3135

Measured Domestic  
Hot Water Temperature  
(Domestic Sensor Required)

55

Measured Outdoor  
Temperature (Outdoor  
Sensor Required)

Standby Mode [Stby]  
View Operation &  
Lockout / Error Codes

Parameter Mode [Para]  
View & Change Settings

Info Mode [Info]  
View Measured and  
Scaling Temperatures

8888

RESET



Mode



Step



Store



+



-



Mode (--- is the measured temperature)

Standby Mode



2x



MODE



INFO



1x

STEP

1180

Measured Supply  
Water Temperature

2x

STEP

2150

Measured Return  
Water Temperature

3x

STEP

3135

Measured Domestic  
Hot Water Temperature  
(Domestic Sensor Required)

4x

STEP

455

Measured Outdoor  
Temperature (Outdoor  
Sensor Required)

5x

STEP

5150

Measured Flue  
Temperature

6x

STEP

6180

Targeted Supply Water  
Temperature

Serial Number



PS80240