

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
SUMP PUMP

SITE AND BLDG #: VA048-01

MECHANIC SIGNATURE: *Tm L*

DATE: *5/9/19*

LOCATION/RM #: *M ECH Room*

START TIME: *10AM*

FINISH TIME: *11AM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
VA048-01	8499	1589	PM-QT-1589	<i>Chicago Pumps</i>			J-1502000-31 1-pc Sump Pump, Electric RM 117	<i>M ECH Room</i>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO			
SPECIAL INSTRUCTIONS						
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X				
2	Schedule outage with operating personnel.	X				
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X				
4	If the material removed from the pump is hazardous, contact the Regional S&EM office for disposal instructions.	X				
5	If strainer cleaning requires removal of pump unit which should be considered a repair and not general maintenance.	X				
6	Excessive sediment and debris, not removed by flushing the pit should be handled on a project basis, and not considered under this standard.	X				
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Remove cover plates and flush pit.	X				
2	Inspect check valve.	X				
3	Inspect interior of pit for cracks.	X				

4	Inspect cover plate gaskets and replace if necessary.			
5	Insure the unit is operating properly, report any deficiencies			
6	Clean up work area and remove all debris.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**