

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR DRYER, REFRIGERATED

SITE AND BLDG #: VA048-02

MECHANIC
SIGNATURE: 

DATE: 07-06-22

LOCATION/RM #: WO#18285 ASSET # 3Y058

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Lubricate valves and replace packing, as needed.	/		
2	Check dryer operating cycle.	/		
3	Inspect and clean heat exchanger, as needed.	/		
4	Check automatic blow down devices.	/		
5	Inspect and replace or reinstall inlet filters.	/A		
6	Check for proper operation and ensure no refrigerant leaks.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: