

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA048 Date of Visit: 7.21.2020

Contractor Personnel on Site:

1. _____	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# _____ WO# 12574

Description of Repairs

Called Angela 7.20.20, no call returned. Arrived at 8.35 am 7.21.2020. (Found Bad Capacitor rated @ 5uf (pulling 199uf), found Burned contactor on compressor side, melted wires. Installed new cap/contactor, wiring Unit works, Supply Temp at 56.7/Return 81.1°. 25.4 degree Temp Split

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Richard Walker Date: 7.21.2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Christina Winfield Date: 7.21.2020

Signed: 

E-Mail: _____

